NISTIR 4705

Fire-Plume-Generated Ceiling Jet Characteristics and Convective Heat Transfer to Ceiling and Wall Surfaces in a Two-Layer Zone-Type Fire Environment: Uniform Temperature Ceiling and Walls

Leonard **Y.** Cooper

Fire-Plume-Generated Ceiling Jet Characteristics and Convective Heat Transfer to Ceiling and Wall Surfaces in a Two-Layer Zone-Type Fire Environment: Uniform Temperature Ceiling and Walls

Leonard Y. Cooper

November **1991**

TABLE OF CONTENTS

LIST OF FIGURES

iv

FIRE-PLUME-GENERATED CEILING JET CHARACTERISTICS AND CONVECTIVE HEAT TRANSFER TO CEILING AND WALL SURFACES IN A TWO-LAYER ZONE-TYPE FIRE ENVIRONMENT: UNIFORM TEMPERATURE CEILING AND WALLS

Leonard Y. Cooper

ABSTRACT

It has been determined by Sandia National Laboratories and the US Nuclear Regulatory Commission that the use of deterministic, multi-room, zone-type fire modeling technology could enhance the reliability of their recent reactor safety risk studies. These studies are confined to the relatively early detection times of fire development when fire-driven ceiling jets and gas-to-ceiling convective heat transfer are expected to play a particularly important role in room-to-room smoke spread and in the response of near-ceiling mounted detection hardware. **A** parameter of concern in these risk analyses is the location of the fire within the space of fire origin. One goal of the analyses is to determine the significance to risk of this fire-position parameter.

This work presents a model to predict the instantaneous rate of convective heat transfer from fire plume gases to the overhead ceiling surface in a room of fire origin. The room is assumed to be a rectangular parallelopiped and, at times of interest, ceiling temperatures are simulated as being uniform. *Also* presented is an estimate of the convective heat transfer, due to ceiling-jet-driven wall flows, to both the upper and lower portions of the walls. The effect on the heat transfer of the location of the fire within the room is taken into account. Finally presented is a model of the velocity and temperature distributions in the ceiling jet.

The model equations were used to develop an algorithm and associated modular computer subroutine to carry out the indicated heat transfer calculations. The subroutine is written in FORTRAN 77 and called CEILHT The algorithm and subroutine are suitable for use in two-layer zone-type compartment fire model computer codes. The subroutine was tested for a variety of fire environments involving a 10^7W fire in a 8m x 8m **x** 4m high enclosure. While the calculated results were plausible, it is important to point out that CEILHT simulations have not been experimentally validated.

Introduction

It has been determined by Sandia National Laboratories and the US Nuclear Regulatory Commission that the use of deterministic, multi-room, zone-type fire modeling technology could enhance the reliability of their recent reactor safety risk studies. These studies are confined to the relatively early detection times of fire development when fire-driven ceiling jets and gas-to-ceiling convective heat transfer are expected to play a particularly important role in room-to-room smoke spread and in the response of near-ceiling mounted detection hardware. A parameter of concern in these risk analyses is the location of the fire within the space of fire origin. One goal of the analyses is to determine the significance to risk of this fire-position parameter. The purpose of this work is to develop and present a means of simulating the heat transfer and flow phenomena *so* that they can be included in two-layer zone-type fire model computer codes.

Consider a room of fire origin in a multi-room facility. At some arbitrary instant during a dynamic fire scenario assume that the fire-generated environment in the room can be reasonably simulated by upper and lower uniform-property layers where the two layers are stably-stratified (i.e., the upper layer temperature is greater than the lower layer temperature).

Consistent with several two-layer zone-type compartment fire model computer codes (see e.g., References [1], [2], and [3]) assume that it is reasonable to simulate the room's ceiling temperature **as** uniform. One objective of this work is to develop an algorithm and associated computer subroutine, useable in such fire models, to predict the instantaneous rate of convective heat transfer from the fire plume to the ceiling surface. In developing the heat transfer simulation it is desired to account for the location of the fire within the room. Estimates of the rates of convective heat transfer to the upper-layer portion of the wall surfaces (i.e., the portion submerged by the upper layer) and lower-layer portion of the wall surfaces will also be provided. A second objective of this work is to provide an estimate of the velocity and temperature distributions in the ceiling jet which is formed by plume/ceiling impingement and radial spread of the plume gases.

Let the room be a rectangular parallelopiped where the geometry is specified and, at a time of interest, assume that the fire environment in the room and the characteristics of the fire itself have been determined.

Room Geometry, Characterization of the Instantaneous State of the Fire, the Fire Plume, and the Fire-Generated Environment

Define a right-handed Cartesian coordinate system with axes X, Y, Z and with origin at a lower corner of the room, i.e., at the floor elevation. Orient the **axes** so that the Z axis is directed upward and the X and Y axes are aligned along the junction of the walls and the floor. Designate the co-ordinates of corner of the room furthest from the origin of the axes as X_m, Y, and Z_{CEIL}. These are the length, width, and ceiling height of the room, respectively. Designate the co-ordinates of the center of the base of the fire as X_{FIRE}, Y_{FIRE}, and Z_{FIRE}.

Characterize and specify the state of the fire-generated environment in the room by: the average densities and assumed uniform temperatures of the upper and lower gas layers, ρ_U, T_U, and ρ_L, T_L, respectively; the temperature of the ceiling surface and the average temperature of the wall surfaces,

T_{CEIL} and T_{WALL}, respectively; and the elevation above the floor of the interface between the two gas layers, Z_{LAYER}. A plan view and an elevation view of the geometry is depicted in Figure 1.

Define and specify Q_{FCONV} as the portion of the total fire energy release rate convected in the fire plume (i.e., the total rate of combustion energy release less the rate of energy radiated from the combustion zone and the plume). If the fire is below the layer interface, $Z_{FIRE} < Z_{LAYER}$, then characterize the mass flow rate and the convected enthalpy flow rate in the plume at Z_{LAYER} as $\dot{M}_{PLUME}$ and $\dot{Q}_{PLUME}$, respectively.

Let $\dot{M}_{PLUME}$ be specified. Then, assuming that the fuel flow rate is negligible compared to $\dot{M}_{PLUME}$,

$$\dot{Q}_{PLUME} = \dot{M}_{PLUME}C_pT_L + \dot{Q}_{FCONV} \tag{1}$$

Overview of Plume/Upper-Layer Interaction and Ceiling Heat Transfer

The buoyant fire plume rises from Z_{FIRE} toward the ceiling. When the fire is below the layer interface, its mass and enthalpy flow, $\dot{M}_{PLUME}$ and $\dot{Q}_{PLUME}$, are assumed to be deposited into the upper layer at Z_{LAYER}. Having penetrated the interface, a portion of the plume typically continues to rise toward the ceiling. As it impinges on the ceiling surface, the plume gases turn and form a relatively high temperature, high velocity, turbulent ceiling jet which flows radially outward along the ceiling and transfers heat to the relatively cool ceiling surface. The ceiling jet is cooled by convection and the ceiling material is heated indepth by conduction. The convective heat transfer rate is a strong function of the radial distance from the point of plume/ceiling impingement, reducing rapidly with increasing radius. It is dependent also on the characteristics of the plume immediately upstream of ceiling impingement.

The relatively high temperature ceiling jet is blocked eventually by the relatively cool wall surfaces. IN THIS **WORK IT IS ASSUMED THAT THE DISTANCE BETWEEN THE PLUME/CEILING IMPINGEMENT POINT AND THE CLOSEST WALL SURFACE IS NEVER LESS THAN** $0.2(Z_{CEIL} - Z_{FIRE})$. Ceiling-jet/wall-surface impingement leads to stagnation-point-type enhancement of jet-to-surface heat transfer [4]. The ceiling jet then turns downward and outward in a complicated flow along the vertical wall surfaces (see [5] and [6]). Convective wall-flow-to-wall-surface heat transfer continues. The descent of the wall flows and the heat transfer from them are stopped eventually by upward buoyant forces. They are then buoyed back upward and mix finally with the upper layer.

Let $\dot{q}''_{CEIL}(X,Y)$ be the instantaneous flux of convective heat transfer from the ceiling jet gases to the ceiling surface and let $\dot{q}''_{CEIL,AVE}$ and $\dot{Q}_{CEIL}$ be its average value and the value of its integral, respectively, over the entire ceiling surface. The first objective of this work is to determine

$$\dot{Q}_{CEIL} = (X_{WALL}Y_{WALL})\dot{q}''_{CEIL,AVE} = \int_0^{X_{WALL}} \int_0^{Y_{WALL}} \dot{q}''_{CEIL}(X,Y)dXdY \tag{2}$$

3

Properties of the Plume in the Upper Layer When $Z_{FIRE} < Z_{LAYER}$

Consider times when the elevation of the fire is below the interface, i.e., when $Z_{FIRE} < Z_{LAYER}$.

As the plume flow enters the upper layer the forces of buoyancy which drove the plume toward the layer interface (i.e., as a result of relatively high-temperature, low-density plume gases being submerged in a relatively cool, high-density lower-layer environment) are reduced immediately because of the increase of temperature of the upper layer environment over that of the lower layer. The continued ascent of the plume gases will be less vigorous, i.e., at reduced velocity, and of higher temperature than it would have been in the absence of the layer. Indeed, some of the penetrating plume flow, will actually be at a lower temperature than T_U. The upper layer buoyant forces on this latter portion of the flow will actually retard and possibly stop its subsequent rise to the ceiling.

The simple point-source Gaussian-distribution plume model of [7] will be used to simulate the plume flow, first immediately below, or upstream of the interface, and then throughout the depth of the upper layer itself.

Consider a Reference-[7]-type point source of buoyancy, with elevation below Z_{LAYER}. Then the plume above such a source will be taken to be equivalent to the plume of our fire (in the sense of having identical mass and enthalpy flow rates at the interface) if the point source strength is Q_{FCONV} and the elevation of the equivalent source, Z_{EQ}, satisfies

$$\dot{M}_{PLUME} = 0.21\rho_L g^{1/2}(Z_{LAYER} - Z_{EQ})^{5/2}\dot{Q}_{EQ}^{*1/3} \tag{3}$$

where $\dot{Q}_{EQ}^*$, a dimensionless measure of the strength of the fire plume at Z_{LAYER}, is defined by

$$\dot{Q}_{EQ}^* = \dot{Q}_{FCONV}/[\rho_L C_p T_L g^{1/2}(Z_{LAYER} - Z_{EQ})^{5/2}] \tag{4}$$

and where C_p **is** the specific heat at constant pressure of the entrained gas, which can be assumed to be identical to that of air.

Solving (3) and (4) for Z_{EQ} and $\dot{Q}_{EQ}^*$ in terms of known variables leads to

$$\dot{Q}_{EQ}^* = [0.21\dot{Q}_{FCONV}/(C_p T_L \dot{M}_{PLUME})]^{3/2} \tag{5}$$

$$Z_{EQ} = Z_{LAYER} - [\dot{Q}_{FCONV}/(\dot{Q}_{EQ}^* \rho_L C_p T_L g^{1/2})]^{2/5} \tag{6}$$

As the plume crosses the interface, the fraction, $\dot{M}^*$, of $\dot{M}_{PLUME}$ which is still buoyant relative to the upper layer environment and presumably continues to rise to the ceiling, entraining upper layer gases along the way, is predicted in [8] to be

$$\dot{M}^* = - \begin{cases} 0 & \text{if } -1 < \sigma \le 0; \\ (1.04599\sigma + 0.360391\sigma^2)/(1. + 1.37748\sigma + 0.360391\sigma^2) & \text{if } \sigma > 0 \end{cases} \quad (7)$$

where the dimensionless parameter a is defined as

$$a = (1 - _{cr} + C_T \dot{Q}_{EQ}^{*2/3})/(\alpha - 1) \quad (8)$$

$$\alpha = T_U/T_L \; ; \; C_T = 9.115 \quad (9)$$

If $\dot{M}^* > 0$, Reference [8] further identifies the parameters necessary to describe plume flow continuation in the upper layer (i.e., between Z_{LAYER} and Z_{CEIL}) according to a Reference-[7]-type point source plume. It has been determined there that this plume can be modeled as being driven by a non-radiating continuation buoyant point source of strength Q' located a distance

$$H = Z_{CEIL} - Z'_{SOURCE} > Z_{CEIL} - Z_{FIRE} \quad (10)$$

below the ceiling in a (downward-) extended upper layer environment of temperature T_U and density ρ_U. The relevant parameters predicted in [8] are

$$\dot{Q}' = \dot{Q}_{FCONV}\sigma\dot{M}^*/(1 + \sigma) \quad (11)$$

$$Z'_{SOURCE} = Z_{LAYER} - (Z_{LAYER} - Z_{EQ})\alpha^{3/5}\dot{M}^{*2/5}[(1 + \sigma)/\sigma]^{1/5} \quad (12)$$

The fire and the equivalent source in the lower layer and the continuation source in the upper layer are depicted in Figure 2. Times during a fire simulation when Eq. (8) predicts $\sigma >> 1$ are related to states of the fire environment when the temperatures above T_L of the radial Gaussian temperature distribution of the plume flow, at the elevation of interface penetration, is predicted to be mostly much larger than $(T_U - T_L)$. Under such circumstances the penetrating plume flow is still very strongly buoyant as it enters the upper layer. The plume will continue to rise to the ceiling and to drive ceiling jet convective heat transfer at rates which differ only slightly (on account of the elevated temperature upper layer environment) from the heat transfer rates which could occur in the absence of an upper layer.

Conditions where Eq. (8) predicts $\sigma < 0$ are related to times during a fire scenario when the temperature of the plume at the elevation of interface penetration is predicted to be uniformly less than T_U. Under such circumstances the penetrating plume flow is nowhere positively (i.e., upward)

buoyant as it enters the upper layer. Thus, while all of this flow is assumed to enter and mix with the upper layer, it is assumed further that none of it rises to the ceiling in a coherent plume, i.e., Q' = 0. For this reason, when $\sigma < 0$ the model precludes to existence of any significant ceiling jet flow and associated convective heat transfer to the ceiling surface.

The above analysis assumes that $Z_{FIRE} < Z_{LAYER}$. However, at the onset of a fire scenario it is typical that $Z_{FIRE} < Z_{LAYER} = Z_{CEIL}$ and α, σ and $\dot{M}^*$ of Eqs. (7)-(9), which depend on the indeterminate initial value of T_U, are themselves undefined. The situation when $Z_{LAYER} = Z_{CEIL}$ is properly taken into account if $\dot{Q}' = \dot{Q}_{FCONV}$ and $Z'_{SOURCE} = Z_{EQ}$.

General Properties of the Plume in the Upper Layer and/or Near the Ceiling

When $Z_{FIRE} < Z_{LAYER} < Z_{CEIL}$, the results of **Eqs.** (11) and (12) allow a description of the fire-driven plume dynamics in the upper layer, up to plume/ceiling impingement at Z_{LAYER}, i.e., by using the continuation point source and the plume model of [7] in the extended upper layer. When $Z_{LAYER} < Z_{FIRE}$, the same plume model is used, but Q' and Z'_{SOURCE} are taken to be the convected buoyant strength of the fire and the actual fire elevation, respectively. Finally, when $Z_{LAYER} = Z_{CEIL}$, the plume dynamics near the ceiling is described by the equivalent point source, which is in the lower layer, and the point source plume model.

All cases can be treated with the following final versions of Eqs. (11) and (12)

$$\dot{Q}' = \begin{cases} \dot{Q}_{FCONV}\sigma\dot{M}^*/(1 + \sigma) & \text{if } Z_{FIRE} < Z_{LAYER} < Z_{CEIL} \\ \dot{Q}_{FCONV} & \text{if } Z_{FIRE} \geq Z_{LAYER} \text{ or if } Z_{LAYER} = Z_{CEIL} \end{cases} \qquad (11')$$

$$Z'_{SOURCE} = \begin{cases} Z_{EQ} & \text{if } Z_{LAYER} = Z_{CEIL}; \\ Z_{LAYER} - (Z_{LAYER} - Z_{EQ})\alpha^{3/5}\dot{M}^{*2/5}[(1 + \sigma)/\sigma]^{1/5} \\ \qquad\qquad\qquad \text{if } Z_{FIRE} < Z_{LAYER} < Z_{CEIL}; \\ Z_{FIRE} & \text{if } Z_{LAYER} \leq Z_{FIRE} < Z_{CEIL} \end{cases} \qquad (12')$$

where Z_{EQ}, $\dot{M}^*$, **a**, and α are calculated from Eqs. (5)-(9).

Calculating the Convective Heat Transfer to the Ceiling

When the fire is below the interface and the interface **is** below the ceiling the method of [9] will be used to calculate $\dot{q}''_{CEIL}$. The method of [9] was developed to treat generic, confined-ceiling, room fire scenarios. The confined ceiling problem is solved by applying the unconfined ceiling heat transfer

6

solution to the problem of an Eq. (11')-(12') equivalent upper layer source in an extended upper layer environment [10, 11]. When the fire is above the interface, the unconfined ceiling methodology applies directly. This solution technique has been used previously in [12] and [13].

The equivalent, extended-upper-layer, unconfined-ceiling flow and heat transfer problem is depicted in the right-hand sketch of Figure 2. It involves the equivalent $\dot{Q}'$ heat source of Eq. (11') located a distance H below the ceiling surface in an extended lower layer environment where H is found from Eqs. (10) and (12'). The objective here is to estimate the $\dot{q}''_{CEIL}(X,Y)$ distribution for the scenario in the latter sketch, and then its Eq. (2) integral over the ceiling surface.

From [10] and [11]

$$\dot{q}''_{CEIL}(X,Y) = h_L(T_{AD} - T_{CEIL}) \tag{13}$$

where T_{AD}, a characteristic ceiling jet temperature, is the temperature that would be measured adjacent to an adiabatic lower ceiling surface, and h_L is a heat transfer coefficient. h_L and T_{AD} are given by

$$h_L/\bar{h} = \begin{cases} 8.82Re_H^{-1/2}Pr^{-2/3}[1 - (5.0 - 0.284Re_H^{0.2})(r/H)] & \text{if } 0 \le r/H < 0.2; \\ 0.283Re_H^{-0.3}Pr^{-2/3}(r/H)^{-1.2}(r/H - 0.0771)/(r/H + 0.279) & \text{if } 0.2 \le r/H \end{cases} \tag{14}$$

$$(T_{AD} - T_U)/(T_U\dot{Q}_H^{*2/3}) = \begin{cases} 10.22 - 14.9r/H & \text{if } 0 \le r/H < 0.2; \\ 8.39f(r/H) & \text{if } 0.2 \le r/H \end{cases} \tag{15}$$

where

$$f(r/H) = [1 - 1.10(r/H)^{0.8} + 0.808(r/H)^{1.6}]/$$
$$[1 - 1.10(r/H)^{0.8} + 2.20(r/H)^{1.6} + 0.690(r/H)^{2.4}] \tag{16}$$

$$r = [(X - X_{FIRE})^2 + (Y - Y_{FIRE})^2]^{1/2} \tag{17}$$

$$\bar{h} = \rho_U C_p g^{1/2}H^{1/2}\dot{Q}_H^{*1/3}; \quad Re_H = g^{1/2}H^{3/2}\dot{Q}_H^{*1/3}/\nu_U; \quad \dot{Q}_H^* = \dot{Q}'/[\rho_U C_p T_U(gH)^{1/2}H^2] \tag{18}$$

In the above, Pr is the Prandtl number (taken to be 0.7) and ν_U is the kinematic viscosity of the upper layer gas which is assumed to have the properties of air. *Also,* $\dot{Q}_H^*$, a dimensionless number, is a measure of the strength of the plume and Re_H is a characteristic Reynolds number of the plume at the elevation of the ceiling.

7

The following estimate for ν_U of air [14] will be used when computing Re, from **Eqs.** (18)

$$\nu_U = [0.04128(10^{-7})T_U^{5/2}]/[T_U + 110.41 \quad \nu_U \text{ in m}^2/\text{s, } T_U \text{ in K} \tag{19}$$

Eqs. (13)-(19) are valid when $Z_{LAYER} < Z_{CEIL}$ and T_U is well defined. When $Z_{LAYER} = Z_{CEIL}$ and T_U is undefined, the results are also valid if T_U is set equal to T_L in these equations. This will yield the correct limiting result for the convective heat transfer to the ceiling, namely, convective heat transfer to the ceiling from an unconfined ceiling jet in a lower layer environment.

Integrating $\dot{q}''_{CEIL}(X,Y)$ according to Eq. (2) yields the desired results for $\dot{Q}_{CEIL}$ and $\dot{q}''_{CEIL,AVE}$.

Calculating the Average Convective Heat Transfer to the Upper and Lower Wall Surfaces

As mentioned above Eq. (2), the ceiling jet is blocked eventually by the relatively cool wall surfaces where ceiling-jet/wall-surface impingement leads to a stagnation-point type of heat transfer enhancement there. In [4] it is estimated that for fires relatively close to a wall (i.e., a wall near to, but outside, the presently restricted $r/H = \mathbf{0.2}$ circle, where ceiling jet velocities are at or near to their largest amplitudes) the rate of heat transfer to the wall, $\dot{q}''_{WALL}$ is more than two times that of the jet-to-local-ceiling-surface heat transfer.

<u>Locations of Normal Ceiling-Jet/Wall Impingement.</u> For the fire scenarios being studied here,.there are four locations where ceiling-jet/wall impingement involves ceiling jet velocities normal to the wall. These locations are identified in Figure 1 as STP1, STP2, STP3, and STP4. At such stagnation points, i.e., at the ceiling/wall junction, an estimate of the heat transfer to the wall is [4]

$$\dot{q}''_{WALL,ST} = h_{ST}(T_{AD} - T_{WALL}) \tag{20}$$

where

$$h_{ST}/\bar{h} = 0.94Re_H^{-0.42}/[(r_{ST}/H)Pr] \tag{21}$$

r_{ST} is the value of r of Eq. (16) at the stagnation point (e.g., $r_{ST} = Y_{FIRE}$ for STP1 in Figure 1), and T_{AD}, $\bar{h}$, and Re, are given in Eqs. (15) and (17).

In *[5]* it is estimated that at locations of normal jet/wall impingement the penetration depth of the downward-directed wall flow is approximately $0.8H$ or Z_{CEIL} (i.e., penetration to the floor), whichever is smaller, and that this result is relatively invariant with the value of r_{ST}/H. Here it is assumed that the heat transfer goes to zero at this penetration depth, and remains zero below this elevation. It is assumed further, that the heat transfer to the wall is linear with elevation, going from $\dot{q}''_{WALL,ST}$ at the ceiling to zero at $Z = Z_{CEIL} - 0.8H$. (It is possible for the latter elevation to be negative, i.e., below the floor, because of the fact that when the fire is in the lower layer, H is based on the

8

elevation of an equivalent point source of buoyancy in the extended upper layer. Consistant with the inequality of Eq. (10), this elevation can actually be below the floor elevation, $Z = 0$. When such is the case, the assumed linear distribution for wall heat transfer is only used between the floor and ceiling elevations.

The above paragraph leads to the following estimate for the average convective heat transfer on the upper wall segment (between Z_{CEIL} and Z_{LAYER}), $\dot{q}''_{WALL,NORM,U}$, and on the lower wall segment (between Z_{LAYER} and the floor), $\dot{q}''_{WALL,NORM,L}$, along vertical lines on a wall where normal ceiling-jet/wall impingement occurs:

$0.8H < Z_{CEIL} - Z_{LAYER}$:

$$\dot{q}''_{WALL,NORM,U} = (\dot{q}''_{WALL,ST}/2)(Z_{CEIL} - 0.8H)/(Z_{CEIL} - Z_{LAYER}) \tag{22}$$

$$\dot{q}''_{WALL,NORM,L} = 0 \tag{23}$$

$Z_{CEIL} - Z_{LAYER} \leq 0.8H < Z_{CEIL}$:

$$\dot{q}''_{WALL,NORM,U} = \dot{q}''_{WALL,ST}[1 - (Z_{CEIL} - Z_{LAYER})/(1.6H)] \tag{24}$$

$$\dot{q}''_{WALL,NORM,L} = (\dot{q}''_{WALL,ST}/2)[0.8H - (Z_{CEIL} - Z_{LAYER})]/Z_{LAYER} \tag{25}$$

$Z_{CEIL} \leq 0.8H$:

$$\dot{q}''_{WALL,NORM,U} = \dot{q}''_{WALL,ST}[1 - (Z_{CEIL} - Z_{LAYER})/(1.6H)] \tag{26}$$

$$\dot{q}''_{WALL,NORM,L} = (\dot{q}''_{WALL,ST}/2)[1.6H - (Z_{CEIL} - Z_{LAYER}) - Z_{CEIL}]/(0.8H) \tag{27}$$

Strategy for Estimating Heat Transfer to the Walls. As noted, Eqs. (22)-(27) can be applied to vertical lines passing through points STP1, STP2, STP3, and STP4. The following strategy is adopted for estimating the average rate of ceiling-jet-driven convective heat transfer to the upper and lower layer wall segments of the room:

1. Use **Eqs.** (20) and (21) to calculate $\dot{q}''_{WALL}$ at the top of the walls near the points STP1, STP2, STP3, and STP4. Then use Eqs. (22)-(27) to calculate the average $\dot{q}''_{WALL}$ along the upper- and lower-layer segments of vertical lines through these points.

2. Estimate $\dot{q}''_{WALL}$ at the top of the walls near the four room corners of the room by assuming normal ceiling-jet/wall impingement there and using Eqs. (20) and (21). For example, use these

9

equations with $r_{ST} = (X^2_{FIRE} + Y^2_{FIRE})^{1/2}$ to estimate the heat ransfer near the top of the walls at $X = Y = 0$. Then use Eqs. (22)-(27) to calculate the average $\dot{q}''_{WALL}$ along the upper- and lower-layer segments of the vertical lines which define these corners.

3. For an upper or lower wall segment between STP1, STP2, STP3, or STP4, and an adjacent corner, estimate the average value of $\dot{q}''_{WALL}$ as the average of the previously computed average values along the vertical bounding "end-lines." Calculate this average for each of the eight upper segments and eight lower segments.

4. For each of the upper-layer segments use the area of the segment and the previously calculated average $\dot{q}''_{WALL}$ to calculate the eight contributions to the total rate of upper-layer wall heat transfer. Sum these contributions and obtain finally $\dot{q}''_{WALL,U,AVE}$, the average flux of heat transfer to the upper-layer portions of the walls. Carry out analogous calculations for $\dot{q}''_{WALL,L,AVE}$, the average flux of heat transfer to the lower-layer portions of the walls.

5. Add the rates of heat transfer to all sixteen upper and lower wall segments and obtain, $\dot{Q}_{WALL}$, the total rate of heat transfer to the wall surfaces.

The details of the above algorithm are presented in Appendix **A.**

It **is** important to point out that in compartment fires there are fluid dynamic effects other than ceiling-jet/wall impingement that can lead to, and dominate the convective heat transfer to walls (see, e.g. [6] and [15]). These effects are not considered in this work.

The Computer Subroutine CEILMT for Carrying out the Heat Transfer Calculations

The model equations of the last two sections were used to develop an algorithm and associated modular computer subroutine to carry out the indicated heat transfer calculations. The subroutine is written in FORTRAN 77 and is called CEILHT A summary flow diagram for the algorithm **is** presented in Figure 3. The algorithm and subroutine are suitable for use in two-layer zone-type compartment fire model computer codes.

CEILHT, which uses the two-dimensional numerical integration subroutine ADAPT [16], is presented in **A**ppendix B. CEILHT has been tested for a variety of instantaneous fire environments involving a 10^7 W fire in a 8m **x** 8m **x** 4m high enclosure. While the calculated results were plausible, it is important to point out that CEILHT simulations have not been experimentally validated.

Velocity and Temperature Distributions in the Ceiling Jet

It is an objective of this work to simulate the velocity and temperature distributions in the ceiling jet. The major interest is to develop a general capability for predicting the dynamic environment local to near-ceiling-deployed fire safety devices, e.g. fusible sprinkler links. Knowledge of this environment would be used in predictions of their thermal response to the fire-generated environment (see, e.g., [13] and [17]).

For relatively smooth-ceiling configurations, assumed to be representative of the rooms of fire origin studied in this work, the ceiling jet flows outward radially from the point of plume/ceiling impingement and its gas velocity and temperature distributions, V_{CJ} and T_{CJ}, respectively, are a function of radius from the impingement point, r, distance below the ceiling, z, and time. Note that it has been shown with some generality that plume-driven ceiling jets are inertially dominated flows from small to moderate r/H values [18].

The Velocity Distribution. Let z be the distance downward from the ceiling surface, i.e., if Z is the elevation above the floor,

$$z = Z_{CEIL} - Z \tag{28}$$

Define the plume/ceiling impingement stagnation zone by r/H < 0.2. Outside the stagnation zone and at **a** given r, V_{CJ} rises rapidly from zero at the ceiling's lower surface, z = 0, to a maximum, V_{MAX}, at a distance z = 0.238, $\delta(r)$ being the distance below the ceiling where $V/V_{MAX} = 1/2$ [5]. In this region outside the stagnation zone, V_{CJ} can be estimated from [5]

When r/H ≥ 0.2:

$$V_{CJ}/V_{MAX} = \begin{cases} (8/7)[z/(0.23\delta)]^{1/7}\{1 - [z/(0.23\delta)]/8\} & \text{if } 0 \le z/(0.23\delta) \le 1; \\ \\ \cosh^{-2}\{(0.23/0.77)\text{arccosh}(2^{1/2})[z/(0.23\delta) - 1]\} & \text{if } 1 \le z/(0.23\delta) \end{cases} \tag{29}$$

$$V_{MAX}/V = 0.85(r/H)^{-1.1}; \quad \delta/H = 0.10(r/H)^{0.9}; \quad V = g^{1/2}H^{1/2}\dot{Q}_{H}^{*1/3} \tag{30}$$

where $\dot{Q}_{H}^{*}$ is defined in Eq. (18). V_{CJ}/V_{MAX} per Eq. (29) is plotted in Figure 4.

Inside the stagnation zone, the fire-driven flow is changing directions from an upward-directed plume flow to a outward-directed ceiling-jet-type flow. There the flow velocity involves generally a significant vertical as well as radial component of velocity with the characteristic velocity being the maximum ceiling jet velocity at r/H = 0.2

When 0 ≤ r/H **c** 0.2:

$$|V_{CJ}| = \text{Order of } [V_{CJ}(r/H = 0.2)] \tag{31}$$

Other considerations are required for a more accurate description of the velocity in the stangnation zone.

11

The Temperature Distribution. Outside of the stagnation zone, i.e., where $r/H \geq 0.2$, and at a given value of r, T_{CJ} changes very rapidly from the temperature of the ceiling's lower surface T_{CEIL}, at z = 0, to a local maximum, T_{MAX}, somewhat below the ceiling surface. We assume that this maximum value of T_{CJ} occurs at the identical distance below the ceiling as does the maximum of V_{CJ}, i.e., at $z = 0.23\delta$. Below this elevation, T_{CJ} drops with increasing distance from the ceiling until it reaches the upper layer temperature, T_U. In this latter outer region of the ceiling jet, the shape of the normalized T_{CJ} distribution, $(T_{CJ} - T_U)/(T_{MAX} - T_U)$, will have the same characteristics as does that of V_{CJ}/V_{MAX}. *Also,* since we are dealing with a turbulent boundary flow it is reasonable to expect that the characteristic thicknesses of the outer region of both the velocity and temperature distributions are the same, being dictated there by the distribution of the turbulent eddies.

For the above reasons we approximate the velocity and temperature distributions as being identical in the outer region of the ceiling jet flow, $0.23\delta \leq z$. In the inner region of the flow, between z = 0 and 0.23δ, we approximate the normalized temperature distribution by a quadratic function of $z/(0.23\delta)$, requiring $T_{CJ} = T_{CEIL}$ at z = 0 and $T_{CJ} = T_{MAX}$, $\partial T_{CJ}/\partial z = 0$ at $z = 0.23\delta$. Thus,

When $r/H \geq 0.2$:

$$\Theta \equiv (T_{CJ}-T_U)/(T_{MAX}-T_U) = \begin{cases} \Theta_S + 2(1 - \Theta_S)[z/(0.23\delta)] - (1 - \Theta_S)[z/(0.23\delta)]^2 \\ \qquad\qquad\qquad\qquad\qquad \text{if } 0 \leq z/(0.23\delta) \leq 1 \quad (32) \\ V_{CJ}/V_{MAX} \qquad\qquad\qquad \text{if } 1 \leq z/(0.23\delta) \end{cases}$$

$$\Theta_S \equiv \Theta(T_{CJ} = T_{CEIL}) = (T_{CEIL} - T_U)/(T_{MAX} - T_U) \tag{33}$$

Note that Θ_S will be negative where the ceiling surface temperature is less than the upper layer temperature, for example, relatively early in the fire when the original ambient-temperature ceiling surface has not yet reached the average temperature of the growing upper layer. *Also,* Θ_S will be greater than 1 where the ceiling surface temperature is greater than T_{MAX}. This is possible, for example, during times of reduced fire size when the fire's near-ceiling plume temperature is reduced significantly, perhaps temporarily, from previous values, but the ceiling surface, heated previously to relatively high temperatures, has not cooled substantially. Plots of Θ per Eq. (32) are presented in Figure **5** for cases when Θ_S is < 0, between 0 and 1, and > 0.

In order to calculate $T_{CJ}(r, z)$ from Eq. (32), it is necessary to determine the one unknown parameter, $T_{MAX}(r)$. This is obtained by invoking conservation of energy. Thus, at an arbitrary r outside the stagnation zone, the total rate of radial outflow of enthalpy (relative to the upper layer temperature) of the ceiling jet within a small subtended angle A6 is equal to the fraction $\Delta\theta/(2\pi)$ of the rate of enthalpy flow in the upper layer portion of the plume, Q', less the integral (from the plume-ceiling impingement point to r) of the flux of convective heat transfer from the ceiling jet to the ceiling surface, i.e.,

When $0.2 \leq r/H$:

$$2\pi r \int_0^\infty \rho_U C_p (T_{CJ} - T_U) V_{CJ} dz \quad = \dot{Q}' - 2\pi \int_0^r \dot{q}''_{CEIL}(r) r dr \quad \equiv (1 - \lambda'_{CONV}) \dot{Q}' \qquad (34)$$

where $\lambda'_{CONV}(r)$ is the fraction of Q' subtended by $\Delta\theta$ and transferred by convection to the ceiling from the point of ceiling impingement to r, i.e.,

$$\lambda'_{CONV}(r) = \quad [2\pi \int_0^r \dot{q}''_{CEIL}(r) r dr] / \dot{Q}' \qquad (35)$$

In the above, Q' has been calculated previously in Eqs. (11'). *Also,* for particular r's of interest, and with $\dot{q}''_{CEIL}$ evaluated according to Eqs. (13)-(19), the integral on the right hand sides of Eqs. (34) and (35) can be determined numerically.

The integral on the left hand side of Eq. **(34)** is calculated using V_{CJ} of Eqs. (29) and (30) and T_{CJ} of Eqs. (32) and (33). From this the desired distribution for T_{MAX} is found finally to be [13]

$$(T_{MAX} - T_U) = 2.6(1 - \lambda'_{CONV})(r/H)^{-0.8} \dot{Q}_H^{*2/3} T_U - 0.090(T_{CEIL} - T_U) \quad \text{if } 0.2 \leq r/H \qquad (36)$$

The above result together with Eqs. *(32)* and (33) represent the desired estimate for $T_{CJ}(r,z)$.

Summary

This work presented a model to predict the instantaneous rate of convective heat transfer from fire plume gases to the overhead ceiling surface in a room of fire origin. The room is assumed to be a rectangular parallelopiped and, at times of interest, ceiling temperatures are simulated as being uniform. *Also* presented is an estimate of the convective heat transfer, due to ceiling-jet-driven wall flows, to the wall surfaces. The effect on the heat transfer of the location of the fire within the room is taken into account. Finally presented was a model of the velocity and temperature distributions in the ceiling jet.

The model equations were used to develop an algorithm and associated modular computer subroutine to carry out the indicated heat transfer calculations. The subroutine is written in FORTRAN *77* and is called CEILHT **A** summary flow diagram for the algorithm is presented in Figure 3. The algorithm and subroutine are suitable for use in two-layer zone-type compartment fire model computer codes. CEILHT, which uses the two-dimensional numerical integration subroutine ADAPT [16] is presented in Appendix B. CEILHT has been tested for a variety of instantaneous fire environments involving a 10^7W fire in a 8m **x** 8m **x** 4m high enclosure. While the calculated results were plausible, it is important to point out that CEILHT simulations have not been experimentally validated.

Acknowledgements

Nomenclature

$A_{WALL,L,N}$ [$A_{WALL,U,N}$]	area of lower- [upper-] layer portion of wall segment N
C_p	specific heat at constant pressure
C_T	9.115
$f(r/H)$	**Eq. (16)**
g	acceleration of gravity
H	distance of continuation source below ceiling, **Eq. (10)**
$\bar{h}$	a characteristic heat transfer coefficient, **Eq. (8)**
h_L	heat transfer coefficient, **Eq. (14)**
h_{ST}	heat transfer coefficient at wall stagnation point, **Eq. (21)**
$\dot{M}^*$	fraction of $\dot{M}_{PLUME}$ which is buoyant in upper layer, **Eq. (7)**
$\dot{M}_{PLUME}$	mass flow rate in plume at Z_{LAYER} when $Z_{FIRE} < Z_{LAYER}$
Pr	Prantl number
$\dot{Q}'$	strength of continuation source, **Eq. (11')**
$\dot{Q}_{CEIL}$	rate of heat transfer to ceiling, **Eq. (2)**
$\dot{Q}^*_{EQ}$	dimensionless strength of plume at Z_{LAYER}
$\dot{Q}^*_H$	dimensionless strength of plume at Z_{CEIL}
$\dot{Q}_{FCONV}$	portion of fire energy release rate convected in plume
$\dot{Q}_{PLUME}$	flow of enthalpy in plume at Z_{LAYER}, **Eq. (1)**
$\dot{Q}_{WALL}$	rate of heat transfer to all wall surfaces. Eq. **(A-6)**
$\dot{q}''_{CEIL}$	flux of rate of heat transfer to ceiling, **Eq. (13)**
$\dot{q}''_{CEIL,AVE}$	average flux of rate of heat transfer to ceiling, **Eq. (2)**
$\dot{q}''_{WALL}$	flux of heat transfer to the wall
$\dot{q}''_{WALL,CRNN,L}$ [$\dot{q}''_{WALL,CRNN,U}$]	average $\dot{q}''_{WALL}$ near corner N in lower [upper] layer

$\dot{q}''_{WALL,L,AVE}$ $[\dot{q}''_{WALL,U,AVE}]$	average $\dot{q}''_{WALL}$ portion of wall in lower [upper] layer, Eq. **(A-5)**
$\dot{q}''_{WALL,L,AVE,N}$ $[\dot{q}''_{WALL,U,AVE,N}]$	average $\dot{q}''_{WALL}$ to portion of wall segment N in the lower [upper] layer
$\dot{q}''_{WALL,NORM,L}$ $[\dot{q}''_{WALL,NORM,U}]$	average $\dot{q}''_{WALL}$ to lower- [upper-] layer portion of wall near vertical line through ceiling-jetball stagnation point
$\dot{q}''_{WALL,ST}$	$\dot{q}''_{WALL}$ at a ceiling-jethall stagnation point, Eq. (20)
$\dot{q}''_{WALL,STPN,L}$ $[\dot{q}''_{WALL,STPN,U}]$	average $\dot{q}''_{WALL}$ to portion of wall in the lower- [upper-] layer along the line passing through stagnation point N **(STPN)**
Re_H	characteristic Reynolds number, Eq. (18)
r	distance from plume/ceiling impingement point
r_{CRNN}	r of corner N (CRNN)
r_{ST}	r of a stagnation point
r_{STPN}	r of stagnation point N (STPN)
T_{AD}	adiabatic ceiling jet temperature, Eq. (15)
T_{CEIL}	temperature of ceiling
T_{CJ}	temperature of ceiling jet
T_L, T_U	temperature of lower [upper] layer
T_{WALL}	average temperature of the wall surfaces
V	characteristic velocity of ceiling jet, Eq. (30)
V_{CJ}	velocity of ceiling jet, Eq. (29)
V_{MAX}	maximum velocity of ceiling jet, Eq. (30)
X,Y,Z	co-ordinates in room, origin at a room corner on the floor
X_{WALL}, Y_{WALL}, and Z_{CEIL}	X, Y, Z of room corner diagonal from origin
X_{FIRE}, Y_{FIRE}, and Z_{FIRE}	X, Y, Z of center of base of fire
Z_{EQ}	Z of equivalent source in lower layer, Eq. (6)

Z_{LAYER}	Z of layer interface
Z'_{SOURCE}	Z of continuation source, **Eq.** (12)
z	distance below ceiling surface, Eq. (28)
a!	T_U/T_L
δ	characteristic ceiling jet thickness, **Eq.** (30)y
Θ	dimensionless T_{CJ}, Eq. (32)
$Θ_S$	Θ at ceiling surface
$λ'_{CONV}$	Eq. (35)
$ν_U$	kinematic viscosity of air, **Eq.** (19)
$ρ_L, ρ_U$	average density of lower [upper] layer
σ	dimensionless parameter, **Eq.** (9)

References

[1] Tanaka, T., A Model of Multiroom Fire Spread, NBSIR **83-2718,** National Institute of Standards and Technology (formerly U.S. National Bureau of Standards), Gaithersburg MD, **1983.**

[2] Jones, W.W., A Multicompartment Model for the Spread of Fire, Smoke, and Toxic Gases, Fire Safety Journal, Vol. **9,** pp. **55-79, 1985.**

[3] Mitler, H.E. and Rockett, J.A., User's Guide to **FIRST,** A Comprehensive Single-Room Fire Model, NBSIR **87-3595,** National Institute of Standards and Technology (formerly U.S. National Bureau of Standards), Gaithersburg MD, **1987.**

[4] Cooper, L.Y., Heat Transfer in Compartment Fires Near Regions of Ceiling-Jet Impingement on a Wall, Journal of Heat Transfer, **111,** pp.455-460, **1989.**

[5] Cooper, L.Y., Ceiling Jet-Driven Wall Flows in Compartment Fires, Combustion Science and Technology, Vol. **62,** pp. **285-296, 1988.**

[6] Jaluria, Y. and Cooper, L.Y., Negatively Buoyant Wall Flows Generated in Enclosure Fires, Progress in Energy and Combustion Science, **15,** pp. **159-182, 1989.**

[7] Zukoski, E.E., Kubota, T., and Cetegen, B., Fire Safety Journal, **3,** p **107, 1981.**

[8] Cooper, L.Y., A Buoyant Source in the Lower of Two, Homogeneous, Stably Stratified Layers, 20th International Symposium on Combustion, Combustion Institute, pp. **1567-1573, 1984.**

[9] Cooper, L.Y., Convective Heat Transfer to Ceilings Above Enclosure Fires, Cooper, L.Y., **19th** Symposium (International) on Combustion, Combustion Institute, pp. **933-939 (1982).**

[10] Cooper, L.Y., Heat Transfer From a Buoyant Plume to an Unconfined Ceiling, Journal of Heat Transfer, Vol. **104,** pp. **446-451,** Aug. **1982.**

[11] Cooper, L.Y. and Woodhouse, A., The Buoyant Plume-Driven Adiabatic Ceiling Temperature Revisited, Journal of Heat Transfer, Vol. **108,** pp. **822-826,** Nov., **1986.**

[12] Cooper, L.Y., and Stroup, D.W., Thermal Response of Unconfined Ceilings Above Growing Fires and the Importance of Convective Heat Transfer, Journal of Heat Transfer, Vol. **109,** pp. **172-178,** Feb. **1987.**

[13] Cooper, L.Y., Estimating the Environment and the Response of Sprinkler Links in Compartment Fires with Draft Curtains and Fusible Link-Actuated Ceiling Vents - Theory, Fire Safety Journal, **16,** pp. **137-163, 1990.**

[14] Hilsenrath, J., Tables of Thermal Properties of Gases, Circular ***564,*** National Bureau of Standards, Gaithersburg, MD, Nov. **1955.**

[15] Cooper, L.Y., On the Significance of a Wall Effect in Enclosures with Growing Fires, Combustion Science and Technology, 40, pp. 19-39, 1954.

[16] Genz, **A.C.** and Malik, A.A., Algorithm 019: ***An*** Adaptive Algorithm for Numerical Integration Over **An** N-Dimensional Rectangular Region, Journal of Computational and Applied Mathematics, **6,** pp. **295-299, 1980.**

[17] Davis, W.D. and Cooper, L.Y., Estimating the Environment and the Response of Sprinkler Links in Compartment Fires with Draft Curtains and Fusible Link-Actuated Ceiling Vents: Part II - User Guide for the Computer Code LAVENT, NISTIR **89-4122,** National Institute of Standards and Technology, Gaithersburg, **1989.**

[18] Alpert, **R.L.,** Turbulent Ceiling Jet Induced by Large-Scale Fires, Combustion Science and Technology, **11,** pp. **197-213, 1975.**

Appendix A: An Algorithm for Estimating the Average Rate of Ceiling-Jet-Driven Convective Heat Transfer to the Upper and Lower Layer Walls

1. Use Eqs. (20) and (21) to calculate $\dot{q}''_{WALL}$ at the top of the walls near the points STP1, STP2, STP3, and STP4. Then use Eqs. (22)-(27) to calculate the average $\dot{q}''_{WALL}$ along the upper- and lower-layer segments of the vertical lines through these points.

    Refer to Figure 6. Designate the radii of points STP1, STP2, etc. as r_{STP1}, r_{STP2}, etc., respectively, and calculate their values:

$$r_{STP1} = Y_{FIRE}$$

$$r_{STP2} = X_{WALL} - X_{FIRE}$$

$$r_{STP3} = Y_{WALL} - Y_{FIRE} \qquad \text{(A-1)}$$

$$r_{STP4} = X_{FIRE}$$

Use r_{STP1} as r_{ST} in Eq. (21) and as r in Eqs. (15) and (17) and determine the corresponding value of $\dot{q}''_{WALL}$ from Eq. (20). Use this latter value as $\dot{q}''_{WALL,ST}$ in Eqs. (22)-(27) and calculate the desired average heat transfer along the upper and lower line segment through point STP1. Designate these as $\dot{q}''_{WALL,STP1,U}$ and $\dot{q}''_{WALL,STP1,L}$, respectively. Carry out analogous calculations and designations for the STP2, STP3, and STP4.

2. Estimate $\dot{q}''_{WALL}$ at the top of the walls near the four comers of the room by assuming that the effect of concentration of the wall flows there can be simulated by normal ceiling-jet/wall impingement, i.e., by using Eqs. (20) and (21). For example, use these equations with $r_{ST} = (X_{FIRE}^2 + Y_{FIRE}^2)^{1/2}$ to estimate the heat ransfer near the top of the walls near X = Y = 0. Then use Eqs. (22)-(27) to calculate the average $\dot{q}''_{WALL}$ along the upper- and lower-layer segments of the vertical lines which define these corners.

    Refer to Figure 6. Designate the radii to the four room corners, CRN1, CRN2, CRN3, and CRN4 as r_{CRN1}, r_{CRN2}, etc., respectively, and calculate their values:

$$r_{CRN1} = (X_{FIRE}^2 + Y_{FIRE}^2)^{1/2}$$

$$r_{CRN2} = [(X_{WALL} - X_{FIRE})^2 + Y_{FIRE}^2]^{1/2}$$

$$r_{CRN3} = [(X_{WALL} - X_{FIRE})^2 + (Y_{WALL} - Y_{FIRE})^2]^{1/2} \qquad \text{(A-2)}$$

$$r_{CRN4} = [X_{FIRE}^2 + (Y_{WALL} - Y_{FIRE})^2]^{1/2}$$

Replace r_{ST} in Eq. (21) and r in Eqs. (15) and (17) by r_{CRN1} and determine the corresponding value of $\dot{q}''_{WALL}$ from Eq. (20). Replace $\dot{q}''_{WALL,ST}$ in Eqs. (22)-(27) by this latter value and calculate the desired average rates of heat transfer along the upper- and lower-layer CRN1 line segment. Designate these as $\dot{q}''_{WALL,CRN1,U}$ and $\dot{q}''_{WALL,CRN1,L}$, respectively. Carry out analogous calculations and designations for the CRN2, CRN3, and CRN4.

3. For an upper- or lower-layer wall segment between STP1, STP2, STP3, or STP4, and an adjacent corner, estimate the average value of $\dot{q}''_{WALL}$ as the average of the previously determined average values along the vertical bounding "end-lines." Calculate this average for each of the eight upper-layer segments and eight lower-layer segments.

Refer to Figure **6**. Number the eight pair of upper- and lower-layer wall segments as shown. Designate the average rates of heat transfer to upper- and lower-layer segment 1 as $\dot{q}''_{WALL,U,AVE,1}$ and $\dot{q}''_{WALL,L,AVE,1}$, respectively. Desigate analogous rates of heat transfer to the other seven pair of wall segments. Calculate:

$$\dot{q}''_{WALL,U,AVE,1} = (\dot{q}''_{WALL,CRN1,U} + \dot{q}''_{WALL,STP1,U})/2$$

$$\dot{q}''_{WALL,L,AVE,1} = (\dot{q}''_{WALL,CRN1,L} + \dot{q}''_{WALL,STP1,L})/2$$

$$\dot{q}''_{WALL,U,AVE,2} = (\dot{q}''_{WALL,CRN2,U} + \dot{q}''_{WALL,STP1,U})/2$$

$$\dot{q}''_{WALL,L,AVE,2} = (\dot{q}''_{WALL,CRN2,L} + \dot{q}''_{WALL,STP1,L})/2$$

$$\dot{q}''_{WALL,U,AVE,3} = (\dot{q}''_{WALL,CRN2,U} + \dot{q}''_{WALL,STP2,U})/2$$

$$\dot{q}''_{WALL,L,AVE,3} = (\dot{q}''_{WALL,CRN2,L} + \dot{q}''_{WALL,STP2,L})/2$$

$$\dot{q}''_{WALL,U,AVE,4} = (\dot{q}''_{WALL,CRN3,U} + \dot{q}''_{WALL,STP2,U})/2$$

$$\dot{q}''_{WALL,L,AVE,4} = (\dot{q}''_{WALL,CRN3,L} + \dot{q}''_{WALL,STP2,L})/2$$

$$\dot{q}''_{WALL,U,AVE,5} = (\dot{q}''_{WALL,CRN3,U} + \dot{q}''_{WALL,STP3,U})/2$$

$$\dot{q}''_{WALL,L,AVE,5} = (\dot{q}''_{WALL,CRN3,L} + \dot{q}''_{WALL,STP3,L})/2$$

$$\dot{q}''_{WALL,U,AVE,6} = (\dot{q}''_{WALL,CRN4,U} + \dot{q}''_{WALL,STP3,U})/2$$

$$\dot{q}''_{WALL,L,AVE,6} = (\dot{q}''_{WALL,CRN4,L} + \dot{q}''_{WALL,STP3,L})/2$$

$$\dot{q}''_{WALL,U,AVE,7} = (\dot{q}''_{WALL,CRN4,U} + \dot{q}''_{WALL,STP4,U})/2$$

$$\dot{q}''_{WALL,L,AVE,7} = (\dot{q}''_{WALL,CRN4,L} + \dot{q}''_{WALL,STP4,L})/2$$

$$\dot{q}''_{WALL,U,AVE,8} = (\dot{q}''_{WALL,CRN1,U} + \dot{q}''_{WALL,STP4,U})/2$$

$$\dot{q}''_{WALL,L,AVE,8} = (\dot{q}''_{WALL,CRN1,L} + \dot{q}''_{WALL,STP4,L})/2$$

(A-3)

21

4. For each of the upper-layer segments use the area of the segment and the previously calculated average $\dot{q}''_{WALL}$ to calculate the eight contributions to the total rate of upper-layer wall heat transfer. Sum these contributions and obtain finally $\dot{q}''_{WALL,U,AVE}$, the average flux of heat transfer to the upper-layer portions of the walls. Carry out analogous calculations for $\dot{q}''_{WALL,L,AVE}$, the average flux of heat transfer to the lower-layer portions of the walls.

Designate the area of upper- and lower-layer wall segment N as $A_{WALL,U,N}$ and $A_{WALL,L,N}$, respectively, and calculate these values:

$$A_{WALL,U,1} = A_{WALL,U,6} = X_{FIRE}(Z_{CEIL} - _{LAYER})$$

$$A_{WALL,L,1} = A_{WALL,L,6} = X_{FIRE}Z_{LAYER}$$

$$A_{WALL,U,2} = A_{WALL,U,5} = (X_{WALL} - X_{FIRE})(Z_{CEIL} - Z_{LAYER})$$

$$A_{WALL,L,2} = A_{WALL,L,5} = (X_{WALL} - X_{FIRE})Z_{LAYER}$$

$$A_{WALL,U,3} = A_{WALL,U,8} = Y_{FIRE}(Z_{CEIL} - Z_{LAYER})$$

$$A_{WALL,L,3} = A_{WALL,L,8} = Y_{FIRE}Z_{LAYER}$$

$$A_{WALL,U,4} = A_{WALL,U,7} = (Y_{WALL} - Y_{FIRE})(Z_{CEIL} - Z_{LAYER})$$

$$A_{WALL,L,4} = A_{WALL,L,7} = (Y_{WALL} - Y_{FIRE})Z_{LAYER}$$

(A-4)

Calculate

$$\dot{q}''_{WALL,U,AVE} = \sum_{N=1}^{8}(A_{WALL,U,N}\dot{q}''_{WALL,AVE,U,N})/ \sum_{N=1}^{8}A_{WALL,U,N}$$

(A-5)

$$\dot{q}''_{WALL,L,AVE} = \sum_{N=1}^{8}(A_{WALL,L,N}\dot{q}''_{WALL,AVE,L,N})/ \sum_{N=1}^{8}A_{WALL,L,N}$$

5. **Add** the rates of heat transfer to all sixteen upper and lower wall segments and obtain, Q_{WALL}, the total rate of heat transfer to the wall surfaces.

$$Q_{WALL} = \dot{q}''_{WALL,U,AVE} \sum_{N=1}^{8}A_{WALL,U,N} + \dot{q}''_{WALL,L,AVE} \sum_{N=1}^{8}A_{WALL,L,N} \qquad \textit{(A-4)}$$

22

Appendix B: The Subroutine CEILHT for Calculating the Convective Heat Transfer in a Two-Layer Fire Environment From Fire Plume Gases to a Uniform Temperature Ceiling and to Uniform Temperature Walls.

Input and Output Variables

The CEILHT input and output variables with definitions and units are listed below. Except for EPS, these are taken from the descriptions presented in the body of the text and in Appendix A.

OUTPUT

$\dot{Q}_{CEIL}$

        rate of heat transfer to ceiling [W]

$\dot{Q}_{WALL}$

        rate of heat transfer to all wall surfaces [W]

$\dot{q}''_{CEIL,AVE}$

        average flux of rate of heat transfer to ceiling [W/m^2]

$\dot{q}''_{WALL,L,AVE}$ [$\dot{q}''_{WALL,U,AVE}$]

        average heat flux to portion of wall in lower [upper] layer [W/m^2]

INPUT

$\dot{M}_{PLUME}$

        mass flow rate in plume at Z_{LAYER} if $Z_{FIRE} < Z_{LAYER}$ [kg/s]

$\dot{Q}_{FCONV}$

        portion of fire energy release rate convected in plume [W]

T_{CEIL}

average temperature of ceiling [K]

T_L, T_U

temperature of lower [upper] layer [K]

T_{WALL}

average temperature of the wall surfaces [K]

X_{WALL}, Y_{WALL}, and Z_{CEIL}

X, Y, Z of room corner diagonal from origin [m]

X_{FIRE}, Y_{FIRE}, and Z_{FIRE}

X, Y, Z of center of base of fire [m]

Z_{LAYER}

Z of layer interface [m]

ρ_L, ρ_U

density of lower [upper] layer [kg/m^3]

Cross-Reference Between Nomenclature and Subroutine Variables

Below is a cross-reference between variables defined in the Nomenclature section and variables used in the subroutine.

NOMENCLATURE VARIABLES	SUBROUTINE VARIABLES
$A_{WALL,L,N}$, $A_{WALL,U,N}$	AWU(N), AWU(N) [m^2]
C_p	CP (use 1000.) [W·s/(kg·K)]

C_T	CT (use 9.115)
$f(r/H)$	F
g	G **(use** 9.8) [m/s^2]
H	H [m]
$\bar{h}$	HTCT [W/(m^2·K)]
h_L	HTCL [W/(m^2·K)]
h_{ST}	HTCST [W/(m^2·K)]
$\dot{M}^*$	MFRAC
$\dot{M}_{PLUME}$	MPLUME [m/s]
Pr	PR
$\dot{Q}'$	QCONT [W]
$\dot{Q}_{CEIL}$	QCEIL [W]
$\dot{Q}_{EQ}^*$	QEQ [W]
$\dot{Q}_H^*$	QH
Q_{FCONV}	QCONV [W]
$\dot{Q}_{PLUME}$	QPLUME [W]
Q_{WALL}	QWALL [W]
$\dot{q}''_{CEIL}$	QFCLG [W/m^2]
$\dot{q}''_{CEIL,AVE}$	QFCLGA [W/m^2]
$\dot{q}''_{WALL}$	QFW [W/m^2]
$\dot{q}''_{WALL,CRNN,L}$, $\dot{q}''_{WALL,CRNN,U}$	QFWCL(N), QFWCU(N) [W/m^2]
$\dot{q}''_{WALL,L,AVE}$, $\dot{q}''_{WALL,U,AVE}$	QFWLA, QFWUA [W/m^2]
$\dot{q}''_{WALL,L,AVE,N}$, $\dot{q}''_{WALL,U,AVE,N}$	QFWLAN(N), QFWUAN(N) [W/m^2]
$\dot{q}''_{WALL,NORM,L}$, $\dot{q}''_{WALL,NORM,U}$	QFWNL, QFWNU [W/m^2]

$\dot{q}''_{WALL,ST}$	QFWST [W/m^2]
$\dot{q}''_{WALL,STPN,L}$, $\dot{q}''_{WALL,STPN,U}$	QFWSL(N), QFWSU(N) [W/m^2]
Re_H	RE
r	R [m]
r_{CRNN}	RC(N) [m]
r_{ST}	RST [m]
r_{STPN}	RS(N) [m]
TAD	TAD [K]
T_{CEIL}	TC [K]
T_{CJ}	TCJ [K]
T_L, T_U	TL, TU [K]
T_{WALL}	TW [K]
V	VCH [m/s]
V_{CJ}	VCJ [m/s]
V_{MAX}	VMAX [m/s]
X,Y,Z	X, Y, Z [m]
X_{WALL}, Y_{WALL}, and Z_{CEIL}	XW, YW, ZC [m]
X_{FIRE}, Y_{FIRE}, and Z_{FIRE}	XF, YF, ZF [m]
Z_{EQ}	ZEQ [m]
Z_{LAYER}	ZLAY [m]
Z'_{SOURCE}	ZS [m]
z	Z [m]
α	ALPHA
δ	DEL [m]

Θ	THETA
Θ_S	THETAS
λ'_{CONV}	LAMC
ν_U	ANU $[m^2/s]$
ρ_L, ρ_U	RHOL, RHOU $[kg/m^3]$
σ	**SIGMA**

The Subroutine CEILHT

On the following pages **is a** listing of **the** subroutine CEILHT

```
      SUBROUTINE CEILHT(
     I                    MPLUME,QCONV,ATC,TL,TU,TW,XW,YW,ZC,AXF,
     I                    AYF,ZF,ZLAY,RHOL,RHOU,EPS,
     O                    QCEIL,QFCLGA,QWALL,QFWLA,QFWUA)
      IMPLICIT DOUBLE PRECISION (A-H,M,O-Z)
      INTEGER RULCLS, MAXPTS, MINPTS
C
C*****************************************************************
C*******WARNING**WARNING**WARNING**WARNING**WARNING**WARNING**WARNING
C***   This subroutine and the function QFCLG used in its called
C***   subroutines use the common blocks AINTCH
C*******WARNING**WARNING**WARNING**WARNING**WARNING**WARNING**WARNING
C***   The algorithm on which this subroutine is based has not been
C***   validated experimentally
C*****************************************************************
C        THIS SUBROUTINE CALCULATES CONVECTIVE HEAT TRANSFER TO
C        THE UNIFORM TEMPERATURE CEILING ABOVE A FIRE IN A PARALLEL-
C        OPIPED ROOM WITH A TWO-LAYER FIRE ENVIRONMENT.  ALSO CALCU-
C        LATED IS THE TOTAL RATE OF HEAT TRANSFER TO THE WALLS AND
C        THE AVERAGE FLUX TO THE UPPER AND LOWER PORTIONS OF THE
C        WALLS.
C
C***   INPUT
C***   -----
C
C***   EPS         RELATIVE ACCURACY FOR COMPUTING THE INTEGRAL
C***               OF THE CEILING HEAT TRANSFER FLUX
C***   MPLUME          MASS FLOW RATE IN THE PLUME AT ZLAY IF ZF <
C***               ZLAY [KG/S]
C***   QCONV       PORTION OF FIRE ENERGY RELEASE RATE CONVECT-
C***               ED IN PLUME [W]
C***   TC          AVERAGE TEMPERATURE OF CEILING [K]
C***   TL,TU       TEMPERATURE OF LOWER, UPPER LAYER [K]
C***   TW          AVERAGE TEMPERATURE OF WALL SURFACES [K]
C***   XW,YW,ZC    CO-ORDINATES OF ROOM CORNER DIAGONALLY OPPO-
C***               SITE TO ORIGIN OF AXES (ORIGIN IS AT A CORN-
C***               ER ON THE FLOOR, WITH X, Y AZES ALONG WALL/
C***               FLOOR JUNCTION AND Z AXES UPWARD) [M]
C***   XF,YF,ZF    CO-ORDINATES OF CENTER OF BASE OF FIRE [M]
C***   ZLAY        ELEVATION ABOVE FLOOR OF LAYER INTERFACE [M]
C***   RHOL,RHOU   DENSITY OF LOWER, UPPER LAYER [KG/M**3]
C
C***   OUTPUT
C***   -----
C
C***   QCEIL       RATE OF HEAT TRANSFER TO CEILING [W]
C***   QFCLGA          AVERAGE FLUX OF HEAT TRANSFER TO CEILING
C***               [W/M**2]
C***   QWALL       RATE OF HEAT TRANSFER TO WALL [W]
C***   QFWLA,QFWUA     AVERAGE FLUX OF HEAT TRANSFER TO LOWER AND
C***               UPPER PORTIONS OF THE WALL SUFACES [W/M**2]
C***
```

```
C***   SOME OTHER DEFINITIONS AND FIXED INPUT IN THIS SUBROUTINE
C***   -----------------------------
c***   ALPHA          TU/TL
C***   AWL(N)             AREA OF LOWER-LAYER PORTION OF WALL SEGMENT N
C***   AWU(N)             AREA OF UPPER-LAYER PORTION OF WALL SEGMENT N
C***   CP             SPECIFIC HEAT OF AIR AT CONSTANT PRESSURE
C***                  [KJ/(KG*K)]
C***   CT             9.115, CONSTANT IN POINT SOURCE PLUME EQN.
C***   G              9.8, ACCELERATION OF GRAVITY [M/S**2]
C***   H              IF LAYER INTERFACE IS BELOW CEILING: DISTANCE
C***                  OF CONTINUATION SOURCE BELOW CEILING; IF LAY-
C***                  ER INTERFACE IS AT CEILING: DISTANCE OF EQUI-
C***                  VALENT SOURCE BELOW CEILING [M]
C***   QCONT          STRENGTH OF CONTINUATION SOURCE [W]
C***   QEQ            DIMENSIONLESS STRENGTH OF PLUME AT ZLAY
c***   QH             DIMENSIONLESS STRENGTH OF PLUME AT ZC
C***   QFWCL(N)       AVERAGE HEAT FLUX TO WALL NEAR CORNER N IN
C***                  THE LOWER LAYER [W/M**2]
C***   QFWCU(N)       AVERAGE HEAT FLUX TO WALL NEAR CORNER N IN
C***                  THE UPPER LAYER [W/M**2]
C***   QFWLAN(N)      AVERAGE HEAT FLUX TO PORTION OF WALL SEGMENT
C***                  N IN THE LOWER LAYER [W/M**2]
C***   QFWUAN(N)      AVERAGE HEAT FLUX TO PORTION OF WALL SEGMENT
C***                  N IN THE UPPER LAYER [W/M**2]
C***   QFWSL(N)       AVERAGE HEAT FLUX TO PORTION OF WALL IN THE
C***                  LOWER LAYER ALONG THE LINE PASSING THROUGH
C***                  STAGNATION POINT N [W/M**2]
C***   QFWSU(N)       AVERAGE HEAT FLUX TO PORTION OF WALL IN THE
C***                  UPPER LAYER ALONG THE LINE PASSING THROUGH
C***                  STAGNATION POINT N [W/M**2]
C***   QFWST          HEAT TRANSFER FLUX TO WALL AT A WALL/CEILING
C***                  -JET STAGNATION POINT [W/M**2]
C***   PR             PRANDTL NUMBER
C***   RC(N)          DISTANCE FROM PLUME/CEILING IMPINGEMENT POINT
C***                  TO CORNER N [M]
C***   RS(N)          DISTANCE FROM PLUME/CEILING IMPINGEMENT POINT
C***                  TO WALL STAGNATION POINT N [M]
C***   THT            TEMPERATURE OF AMBIENT IN UNCONFINED CEILING
C***                  HEAT TRANSFER PROBLEM, EITHER TL OR TU [K]
C***   ZEQ            ELEVATION ABOVE FLOOR OF EQUIVALENT SOURCE
C***                  IN LOWER LAYER [M]
C***   ZS             ELEVATION ABOVE FLOOR OF CONTINUATION SOURCE
C***                  [M]
C
          DIMENSION A(2), B(2)
          PARAMETER (LENWRK=10000)
          DIMENSION WRKSTR(LENWRK)
          EXTERNAL QFCLG
        PARAMETER(PI=3.141592D0,G=9.8D0,CT=9.115D0,CP=1000.D0,
       +             PR=0.7D0)
        DIMENSION AWL(8),AWU(8),QFWCL(4),QFWCU(4),QFWLAN(8),
       +             QFWUAN(8),QFWSL(4),QFWSU(4),RC(4),RS(4)
```

```fortran
      COMMON/AINTCH/H,HTCT,THT,THTQHP,C1,C2,C3,XF,YF,TC
      XF=AXF
      YF=AYF
      TC=ATC
      IF(ZF.LT.ZLAY)THEN
C         fire is below layer interface***********************
          QEQ=(0.21D0*QCONV/(CP*TL*MPLUME))**(3.D0/2.D0)
          ZEQ=ZLAY-(QCONV/(QEQ*RHOL*CP*TL*DSQRT(G)))**
     +                                  (2.D0/5.D0)
          IF(ZLAY.LT.ZC)THEN
C             layer interface is below ceiling*************
              ALPHA=TU/TL
              IF (ALPHA.LE.1.D0)THEN
                  MFRAC=1.D0
                  QCONT-QCONV
                  ZS-ZEQ
                  THT-TU
                  RHOHT=RHOU
              ELSE
                  SIGMA=(1.D0-ALPHA+CT*
     +                      (QEQ**(2.D0/3.D0)))/(ALPHA-1.D0)
                  IF(SIGMA.GT.0.D0)THEN
                      SSQ=SIGMA**2.D0
                      TOP=1.04599D0*SIGMA+
     +                          0.360391D0*SSQ
                      BOTTOM=1.D0+1.37748D0*SIGMA+
     +                          0.360391D0*SSQ
                      MFRAC=TOP/BOTTOM
                      QCONT=QCONV*SIGMA*MFRAC/
     +                          (1.D0+SIGMA)
                      ZS=ZLAY-(ZLAY-ZEQ)*
     +                          (ALPHA**(3.D0/5.D0))*
     +                          (MFRAC**(2.D0/5.D0))*
     +                          (((1.D0+SIGMA)/SIGMA)
     +                              **(1.D0/5.D0))
                      THT-TU
                      RHOHT=RHOU
                  ELSE
C                     no plume penetration**********
                      MFRAC=0.D0
                      QCEIL=0.D0
                      QFCLGA=0.D0
                      QWALL=0.D0
                      QFWLA=0.D0
                      QFWUA=0.D0
                      RETURN
                  ENDIF
              ENDIF
          ELSE
C             layer interface is at ceiling***************
              QCONT-QCONV
              ZS=ZEQ
```

```
                  THT=TL
                  RHOHT=RHOL
               ENDIF
         ELSE
C             fire is at or above layer interface*****************
               IF(ZF.LT.ZC)THEN
C                  fire is below ceiling*********************
                  QCONT=QCONV
                  ZS=ZF
                  THT-TU
                  RHOHT=RHOU
               ELSE
C                  fire is at ceiling************************
                  QCEIL=0.D0
                  QFCLGA=0.D0
                  QWALL=0.D0
                  QFWLA=0.DO
                  QFWUA=0.DO
                  RETURN
               ENDIF
         ENDIF
         H=ZC-ZS
         SQRTGH=(G*H)**(1.D0/2.DO)
         QH=QCONT/(RHOHT*CP*THT*SQRTGH*(H**2.DO))
         QHP=(QH**(1.D0/3.DO))
         HTCT=RHOHT*CP*SQRTGH*QHP
         ANU=(0.04128D-7*(THT**(5.D0/2.D0)))/(THT+110.4D0)
         RE=SQRTGH*H*QHP/ANU
         THTQHP=THT*(QHP**2.DO)
         PRP=PR**(2.D0/3.DO)
         C1=8.82D0/(DSQRT(RE)*PRP)
         C2=5.D0-0.284D0*(RE**0.2D0)
         C3=0.283032655D0/((RE**0.3D0)*PRP)
         C4=0.94D0/((RE**0.42D0)*PR)
               NDIM = 2
               MAXPTS = 25000
               RULCLS =   2**NDIM+2*NDIM**2+6*NDIM+1
               ITEMP1 = (2*NDIM+3)*(1+MAXPTS/RULCLS)/2
               ITEMP = 2**NDIM+2*NDIM**2+6*NDIM+1
               QCEIL=0.
               DO 5 I=1,4
               MINPTS = 10
               IF(I.EQ.1)THEN
                     A(1) = 0.
                     A(2)  = 0.
                     B(1) = XF
                     B(2) = YF
         ELSE
               IF(I.EQ.2)THEN
                     A(1) = XF
                     A(2) = 0.
                     B(1) = XW
```

31

```
                            B(2)  = YF
                ELSE
                        IF(I.EQ.3)THEN
                                A(1)  = XF
                                A(2)  = YF
                                B(1)  = XW
                                B(2)  = YW
                        ELSE
                                A(1)  = 0.
                                A(2)  = YF
                                B(1)  = XF
                                B(2)  = YW
                        ENDIF
                ENDIF
        ENDIF
        *       CALL ADAPT(NDIM,A,B,MINPTS,MAXPTS,QFCLG,EPS,RELERR,LENWRK,
                WRKSTR,ADDQCEIL,IFAIL)
        QCEIL=QCEIL+ADDQCEIL
5       CONTINUE
                IF(IFAIL.GT.0) QCEIL=0.D0    .
                QFCLGA=QCEIL/(XW*YW)
C***  Now calculate wall heat transfer:
C***  Step 1.
C***  Calculate radii at wall stagnation points:
        RS(1)=YF
        RS(2)=XW-XF
        RS(3)=YW-YF
        RS(4)=XF
        RMIN=MIN(RS(1),RS(2),RS(3),RS(4))
        IF (RMIN.LT.0.2*(ZC-ZF))THEN
        WRITE(6,*)'IMPINGEMENT POINT IS CLOSER TO A WALL THAN 0.2 OF ',
        +  'FIRE-TO-CEILING DISTANCE'
        ENDIF
C***  Calculate average heat transfer fluxes to lower and upper
C***  walls along the vertical lines passing through the four wall/
C***  ceiling-jet stagnation points:
        DO 10 N=1,4
        RDH=RS(N)/H
        CALL SQFWST(RDH,H,C4,THT,HTCT,THTQHP,TW,QFWSL(N),QFWSU(N),
        +               ZC,ZLAY)
10      CONTINUE
C***  Step 2.
C***  Calculate radii at room corners:
        RC( 1)=DSQRT(XF**2.D0+YF**2.D0)
        RC(2)=DSQRT((XW-XF)**2.D0+YF**2.D0)
        RC(3)=DSQRT((XW-XF)**2.D0+(YW-YF)**2.D0)
        RC(4)=DSQRT(XF**2.D0+(YW-YF)**2.D0)
C***  Calculate average heat transfer fluxes to lower and upper
C***  walls along the vertical lines passing through the four room
C***  corners by assuming that the heat transfer there is as along
C***  a line passing through a point of normal ceiling-jet/wall im-
C***  pingement.
```

```fortran
      DO 20 N=1,4
      RDH=RC(N)/H
      CALL SQFWST(RDH,H,C4,THT,HTCT,THTQHP,TW,QFWCL(N),QFWCU(N),
     +                ZC,ZLAY)
20    CONTINUE
```

C*** Step 3.
C*** Calculate the average heat transfer fluxes to the lower and
C*** upper portions of the eight wall segments bounded by the room
C*** corners and the the vertical lines passing through the points
C*** of normal wall/ceiling-jet impingement.

```fortran
      QFWUAN(1)=(QFWCU(1)+QFWSU(1))/2.DO
      QFWLAN(1)=(QFWCL(1)+QFWSL(1))/2.DO
      QFWUAN(2)=(QFWCU(2)+QFWSU(1))/2.DO
      QFWLAN(2)=(QFWCL(2)+QFWSL(1))/2.DO
      QFWUAN(3)=(QFWCU(2)+QFWSU(2))/2.DO
      QFWLAN(3)=(QFWCL(2)+QFWSL(2))/2.DO
      QFWUAN(4)=(QFWCU(3)+QFWSU(2))/2.DO
      QFWLAN(4)=(QFWCL(3)+QFWSL(2))/2.DO
      QFWUAN(5)=(QFWCU(3)+QFWSU(3))/2.DO
      QFWLAN(5)=(QFWCL(3)+QFWSL(3))/2.DO
      QFWUAN(6)=(QFWCU(4)+QFWSU(3))/2.DO
      QFWLAN(6)=(QFWCL(4)+QFWSL(3))/2.DO
      QFWUAN(7)=(QFWCU(4)+QFWSU(4))/2.DO
      QFWLAN(7)=(QFWCL(4)+QFWSL(4))/2.DO
      QFWUAN(8)=(QFWCU(1)+QFWSU(4))/2.DO
      QFWLAN(8)=(QFWCL(1)+QFWSL(4))/2.DO
```

C*** Step 4.
C*** For each of the upper layer segments use the area of the seg-
C*** ment and the previously calculated average heat transfer
C*** flux to calculate the eight contributions to theto the total
C*** rate of upper-layer wall heat transfer. Sum these contribu-
C*** tions and obtain finally the average rate of heat transfer to
C*** the upper-layer portions of the walls. Carry out analogous
C*** calculations for the lower wall surfaces. Add rates of heat
C*** transfer to all 16 wall surface segments and obtain total
C*** rate of heat transfer to the wall.

```fortran
      AWL( 1)=XF*ZLAY
      AWU(1)=XF*(ZC-ZLAY)
      AWL(2)=(XW-XF)*ZLAY
      AWU(2)=(XW-XF)*(ZC-ZLAY)
      AWL( 3)=YF*ZLAY
      AWU(3)=YF*(ZC-ZLAY)
      AWL(4)=(YW-YF)*ZLAY
      AWU(4)=(YW-YF)*(ZC-ZLAY)
      AWL(5)=AWL(2)
      AWU(5)=AWU(2)
      AWL(6)=AWL(1)
      AWU(6)=AWU(1)
      AWL(7)=AWL(4)
      AWU(7)=AWU(4)
      AWL(8)=AWL(3)
```

```
        AWU(8)=AWU(3)
        SUMAQL=0.D0
        SUMAQU=0.D0
        SUMAL=0.D0
        SUMAU=0.D0
        DO 30 N=1,8
        SUMAQL=AWL(N)*QFWLAN(N)+SUMAQL
        SUMAQU=AWU(N)*QFWUAN(N)+SUMAQU
        SUMAL=AWL(N)+SUMAL
        SUMAU=AWU(N)+SUMAU
30      CONTINUE
        IF(SUMAL.LE.0.D0)THEN
                QFWLA=0.D0
        ELSE
                QFWLA=SUMAQL/SUMAL
        ENDIF
        IF(SUMAU.LE.0.D0)THEN
                QFWUA=0.D0
        ELSE
                QFWUA=SUMAQU/SUMAU
        ENDIF
        QWALL=SUMAQL+SUMAQU
        RETURN
        END
C*************************************************************
C*************************************************************
C*************************************************************
        SUBROUTINE SQFWST(RDH,H,C4,THT,HTCT,THTQHP,TW,QFWLOW,QFWUP,
       +                   ZC,ZLAY)
C***    Calculate average heat transfer fluxes to lower and upper
C***    walls along a vertical line passing through a wall/ceiling-
C***    jet stagnation point
        IMPLICIT DOUBLE PRECISION (A-H,M,O-Z)
        F=(1.D0-1.1D0*(RDH**0.8D0)+0.808D0*(RDH**1.6D0))/
       +          (1.D0-1.1D0*(RDH**0.8D0)+2.2D0*(RDH**1.6D0)+
       +                              0.69D0*(RDH**2.4D0))
        IF(RDH.LT.0.2D0)THEN
                TADDIM=10.22D0-14.9D0*RDH
        ELSE
                TADDIM=8.39D0*F
        ENDIF
        HTCL=C4*HTCT/RDH
        TAD-TADDIM*THTQHP+THT
        QFWST=HTCL*(TAD-TW)
        IF(ZC.LE.0.8D0*H)THEN
                QFWLOW=(QFWST/2.D0)*(1.6D0*H-(ZC-ZLAY)-ZC)/(0.8D0*H)
                QFWUP=QFWST*(1.D0-(ZC-ZLAY)/(1.6D0*H))
        ELSE
                IF((ZC-ZLAY).GT.0.8D0*H)THEN
                        QFWLOW=0.D0
                        QFWUP=(QFWST/2.D0)*(ZC-0.8D0*H)/(ZC-ZLAY)
                ELSE
```

```
                   QFWLOW=(QFWST/2.D0)*(0.8D0*H-(ZC-ZLAY))/ZLAY
                   QFWUP=QFWST*(1.D0-(ZC-ZLAY)/(1.6D0*H))
              ENDIF
        ENDIF
        RETURN
        END
C****-*****************************************************************
C*******************************************************************
C*****************************************************************
      SUBROUTINE ADAPT(NDIM,A,B,MINPTS,MAXPTS,FUNCTN,EPS,RELERR,LENWRK,
     * WRKSTR,FINEST,IFAIL)
      IMPLICIT DOUBLE PRECISION (A-H,O-Z)
C***BEGIN PROLOGUE ADAPT
C  ADAPTIVE MULTIDIMENSIONAL INTEGRATION SUBROUTINE
C           AUTHOR: A. C. GENZ, Washington State University
C                     19 March 1984
C************** PARAMETERS FOR ADAPT  ******************************
C***** INPUT PARAMETERS
C  NDIM    NUMBER OF VARIABLES, MUST EXCEED 1, BUT NOT EXCEED 20
C  A.      REAL ARRAY OF LOWER LIMITS, WITH DIMENSION NDIM
C  B       REAL ARRAY OF UPPER LIMITS, WITH DIMENSION NDIM
C  MINPTS  MINIMUM NUMBER OF FUNCTION EVALUATIONS TO BE ALLOWED.
C          ON THE FIRST CALL TO ADAPT MINPTS SHOULD BE SET TO A
C          NON NEGATIVE VALUE. (CAUTION... MINPTS IS ALTERED BY ADAPT)
C          IT IS POSSIBLE TO CONTINUE A CALCULATION TO GREATER ACCURACY
C          BY CALLING ADAPT AGAIN BY DECREASING EPS (DESCRIBED BELOW)
C          AND RESETTING MINPTS TO ANY NEGATIVE VALUE.
C          MINPTS MUST NOT EXCEED MAXPTS.
C  MAXPTS  MAXIMUM NUMBER OF FUNCTION EVALUATIONS TO BE ALLOWED,
C          WHICH MUST BE AT LEAST RULCLS, WHERE
C          RULCLS = 2**NDIM+2*NDIM**2+6*NDIM+1
C
C              FOR NDIM =  2   3   4   5   6   7   8   9   10
C               MAXPTS >=  25  45  73 113 173 269 433 729 1285
C          A suggested value for MAXPTS is 100 times the above values,
C
C  FUNCTN  EXTERNALLY DECLARED USER DEFINED FUNCTION TO BE INTEGRATED.
C          IT MUST HAVE PARAMETERS (NDIM,Z), WHERE Z IS A REAL ARRAY
C          OF DIMENSION NDIM.
C  EPS     REQUIRED RELATIVE ACCURACY
C  LENWRK  LENGTH OF ARRAY WRKSTR OF WORKING STORAGE, THE ROUTINE
C          NEEDS (2*NDIM+3)*(1+MAXPTS/RULCLS)/2 FOR LENWRK IF
C          MAXPTS FUNCTION CALLS ARE USED.
C          FOR GUIDANCE, IF YOU SET MAXPTS TO 100*RULCLS (SEE TABLE
C          ABOVE) THEN ACCEPTABLE VALUES FOR LENWRK ARE
C
C              FOR NDIM =  2     3     4     5     6     7     8     9
C              LENWRK =  357   561  1785  3417  6681 13209 26265 52377
C
C***** OUTPUT PARAMETERS
C  MINPTS  ACTUAL NUMBER OF FUNCTION EVALUATIONS USED BY ADAPT
C  WRKSTR  REAL ARRAY OF WORKING STORAGE OF DIMENSION (LENWRK).
```

35

```
C  RELERR   ESTIMATED RELATIVE ACCURACY OF FINEST
C  FINEST   ESTIMATED VALUE OF INTEGRAL
C  IFAIL    IFAIL=0 FOR NORMAL EXIT, WHEN ESTIMATED RELATIVE ACCURACY
C                   RELERR IS LESS THAN EPS WITH MAXPTS OR LESS FUNCTION
C                   CALLS MADE.
C           IFAIL=1 IF MAXPTS WAS TOO SMALL FOR ADAPT TO OBTAIN THE
C                   REQUIRED RELATIVE ACCURACY EPS.  IN THIS CASE ADAPT
C                   RETURNS A VALUE OF FINEST WITH ESTIMATED RELATIVE
C                   ACCURACY RELERR.
C           IFAIL=2 IF LENWRK TOO SMALL FOR MAXPTS FUNCTION CALLS.  IN
C                   THIS CASE ADAPT RETURNS A VALUE OF FINEST WITH
C                   ESTIMATED ACCURACY RELERR USING THE WORKING STORAGE
C                   AVAILABLE, BUT RELERR WILL BE GREATER THAN EPS.
C           IFAIL=3 IF NDIM ) 2, NDIM \ 20, MINPTS \ MAXPTS,
C                   OR MAXPTS ) RULCLS.
C***********************************************************************
C***END PROLOGUE ADAPT
      EXTERNAL FUNCTN
C*****  FOR DOUBLE PRECISION CHANGE REAL TO DOUBLE PRECISION IN THE
C          NEXT STATEMENT.
      DIMENSION A(NDIM), B(NDIM), CENTER(20)
      DIMENSION WIDTH(20), WRKSTR(LENWRK)
      INTEGER DIVAXO, DIVAXN, DIVFLG, FUNCLS, IFAIL, INDEX1,
     * INDEX2, J , K , LENWRK, MAXCLS, MAXPTS, MINPTS, NDIM,
     * RGNSTR, RULCLS, SBRGNS, SBTMPP, SUBRGN, SUBTMP
      IFAIL-3
      RELERR=1
      FUNCLS=0
      IF(NDIM.LT.2.OR.NDIM.GT.20) GOTO 300
      IF(MINPTS.GT.MAXPTS) GOTO 300
C
C*****   INITIALISATION OF SUBROUTINE
C
      ZERO-0
      ONE=1
      TWO-2
      HALF=ONE/TWO
      RGNSTR=2*NDIM+3
      ERRMIN = ZERO
      MAXCLS =  2**NDIM+2*NDIM**2+6*NDIM+1
      MAXCLS = MINO(MAXCLS,MAXPTS)
      DIVAXO=0
C
C*****  END SUBROUTINE INITIALISATION
      IF(MINPTS.LT.0) SBRGNS=WRKSTR(LENWRK-1)
      IF(MINPTS.LT.0) GOTO 280
      DO 30 J=1,NDIM
        WIDTH(J)=(B(J)-A(J))*HALF
   30   CENTER(J)-A(J)+WIDTH(J)
      FINEST-ZERO
      WRKSTR(LENWRK)=ZERO
      DIVFLG=1
```

```
         SUBRGN=RGNSTR
         SBRGNS=RGNSTR
     40  CALL BSRL(NDIM,CENTER,WIDTH,FUNCTN,MAXCLS,RULCLS,
      .              ERRMIN,RGNERR,RGNVAL,DIVAXO,DIVAXN)
        FINEST=FINEST+RGNVAL
        WRKSTR(LENWRK)=WRKSTR(LENWRK)+RGNERR
        FUNCLS = FUNCLS + RULCLS
C
C*****  PLACE RESULTS OF BASIC RULE INTO PARTIALLY ORDERED LIST
C*****  ACCORDING TO SUBREGION ERROR
        IF(DIVFLG.EQ.1) GO TO 230
C
C*****  WHEN DIVFLG=0 START AT TOP OF LIST AND MOVE DOWN LIST TREE TO
C         FIND CORRECT POSITION FOR RESULTS FROM FIRST HALF OF RECENTLY
C         DIVIDED SUBREGION
    200 SUBTMP=2*SUBRGN
        IF(SUBTMP.GT.SBRGNS) GO TO 250
         IF(SUBTMP.EQ.SBRGNS) GO TO 210
         SBTMPP=SUBTMP+RGNSTR
         IF(WRKSTR(SUBTMP).LT.WRKSTR(SBTMPP)) SUBTMP=SBTMPP
    210  IF(RGNERR.GE.WRKSTR(SUBTMP)) GO TO 250
         DO 220 K=1,RGNSTR
           INDEX1=SUBRGN-K+1
           INDEX2=SUBTMP-K+1
    220     WRKSTR(INDEX1)=WRKSTR(INDEX2)
         SUBRGN-SUBTMP
        GOTO 200
C
C^^^^^  WHEN DIVFLG=1 START AT BOTTOM RIGHT BRANCH AND MOVE UP LIST
C         TREE TO FIND CORRECT POSITION FOR RESULTS FROM SECOND HALF OF
C         RECENTLY DIVIDED SUBREGION
    230 SUBTMP=(SUBRGN/(RGNSTR*2))*RGNSTR
        IF(SUBTMP.LT.RGNSTR) GO TO 250
        IF(RGNERR.LE.WRKSTR(SUBTMP)) GO TO 250
         DO 240 K=1,RGNSTR
           INDEX1=SUBRGN-K+1
           INDEX2=SUBTMP-K+1
    240     WRKSTR(INDEX1)=WRKSTR(INDEX2)
         SUBRGN=SUBTMP
        GOTO 230
C*****  STORE RESULTS OF BASIC RULE IN CORRECT POSITION IN LIST
    250 WRKSTR(SUBRGN)=RGNERR
        WRKSTR(SUBRGN-1)=RGNVAL
        WRKSTR(SUBRGN-2)=DIVAXN
        DO 260 J=1,NDIM
          SUBTMP=SUBRGN-2*(J+1)
          WRKSTR(SUBTMP+1)=CENTER(J)
    260    WRKSTR(SUBTMP)=WIDTH(J)
        IF(DIVFLG.EQ.1) GO TO 270
C*****  WHEN DIVFLG=0 PREPARE FOR SECOND APPLICATION OF BASIC RULE
        CENTER(DIVAXO)=CENTER(DIVAXO)+TWO*WIDTH(DIVAXO)
        SBRGNS=SBRGNS+RGNSTR
```

```
      SUBRGN=SBRGNS
      DIVFLG=1
C****  LOOP BACK TO APPLY BASIC RULE TO OTHER HALF OF SUBREGION
      GO TO 40
C
C*****  END ORDERING AND STORAGE OF BASIC RULE RESULTS
C*****  MAKE CHECKS FOR POSSIBLE TERMINATION OF ROUTINE
C
C******  FOR DOUBLE PRECISION CHANGE ABS TO DABS IN THE NEXT STATEMENT
  270 RELERR-ONE
      IF(WRKSTR(LENWRK).LE.ZERO) WRKSTR(LENWRK)=ZERO
      IF(ABS(FINEST).NE.ZERO) RELERR=WRKSTR(LENWRK)/ABS(FINEST)
      IF(RELERR.GT.ONE) RELERR-ONE
      IF(SBRGNS+RGNSTR.GT.LENWRK-2) IFAIL=2
      IF(FUNCLS+FUNCLS*RGNSTR/SBRGNS.GT.MAXPTS) IFAIL-1
      IF(RELERR.LT.EPS.AND.FUNCLS.GE.MINPTS) IFAIL=0
      IF(IFAIL.LT.3) GOTO 300
C
C*****  PREPARE TO USE BASIC RULE ON EACH HALF OF SUBREGION WITH LARGEST
C       ERROR
  280 DIVFLG=0
      SUBRGN=RGNSTR
      SUBTMP = 2*SBRGNS/RGNSTR
      MAXCLS = MAXPTS/SUBTMP
      ERRMIN = ABS(FINEST)*EPS/FLOAT(SUBTMP)
      WRKSTR(LENWRK)=WRKSTR(LENWRK)-WRKSTR(SUBRGN)
      FINEST=FINEST-WRKSTR(SUBRGN-1)
      DIVAXO=WRKSTR(SUBRGN-2)
      DO 290 J=1,NDIM
        SUBTMP=SUBRGN-2*(J+1)
        CENTER(J)=WRKSTR(SUBTMP+1)
  290   WIDTH(J)=WRKSTR(SUBTMP)
      WIDTH(DIVAXO)=WIDTH(DIVAXO)*HALF
      CENTER(DIVAXO)=CENTER(DIVAXO)-WIDTH(DIVAXO)
C
C*****  LOOP BACK TO APPLY BASIC RULE
C
      GOTO 40
C
C*****  TERMINATION POINT
C
  300 MINPTS=FUNCLS
      WRKSTR(LENWRK-1)=SBRGNS
      RETURN
      END
C*****************************************************************
C*****************************************************************
C*****************************************************************
      SUBROUTINE BSRL(S,CENTER,HWIDTH,F,MAXVLS,FUNCLS,
     *               ERRMIN,ERREST,BASEST,DIVAXO,DIVAXN)
      IMPLICIT DOUBLE PRECISION (A-H,O-Z)
      EXTERNAL F
```

```
       INTEGER S , DIVAXN, DIVAXO, FUNCLS, INTCLS, I , MINDEG, MAXDEG,
     * MAXORD, MINORD, MAXCLS
       DOUBLE PRECISION INTVLS
       DIMENSION CENTER(S), HWIDTH(S)
       DIMENSION INTVLS(20), Z(20), FULSMS(200), WEGHTS(200)
       MAXDEG = 12
       MINDEG = 4
       MINORD = 0
       ZERO = 0
       ONE = 1
       TWO = 2
       THREE = 3
       FIVE = 5
       TEN = 10
       DO 10 MAXORD = MINDEG,MAXDEG
         CALL SYMRL(S, CENTER, HWIDTH, F, MINORD, MAXORD, INTVLS,
     *    INTCLS, 200, WEGHTS, FULSMS, IFAIL)
         IF (IFAIL.EQ.2) GOTO 20
         ERREST = ABS(INTVLS(MAXORD)-INTVLS(MAXORD-1))
         ERRORM = ABS(INTVLS(MAXORD-1)-INTVLS(MAXORD-2))
         IF (ERREST.NE.ZERO)
     *   ERREST = ERREST*AMAX1(ONE/TEN,ERREST/AMAX1(ERREST/TWO,ERRORM))
         IF (ERRORM.LE.FIVE*ERREST) GOTO 20
         IF (2*INTCLS.GT.MAXVLS) GOTO 20
         IF (ERREST.LT.ERRMIN) GOTO 20
P0     CONTINUE
20  DIFMAX = -1
       X1 = ONE/TWO**2
       X2 = THREE*X1
       DO 30 I = 1,S
        Z(I) = CENTER(I)
30    CONTINUE
       SUMO = F(S,Z)
       DO 40 I = 1,S
        Z(I) = CENTER(I) - X1*HWIDTH(I)
        SUM1 = F(S,Z)
        Z(I) = CENTER(I) + X1*HWIDTH(I)
        ████ = SUM1 + F(S,Z)
        Z(I) = CENTER(I) - X2*HWIDTH(I)
        SUM2 = F(S,Z)
        Z(I) = CENTER(I) + X2*HWIDTH(I)
        SUM2 = SUM2 + F(S,Z)
        Z(I) = CENTER(I)
        DIF = ABS((SUM1-TWO*SUMO) - (X1/X2)**2*(SUM2-TWO*SUMO))
        IF (DIF.LT.DIFMAX) GOTO 40
         DIFMAX = DIF
         DIVAXN = I
40    CONTINUE
       IF (SUMO.EQ.SUMO+DIFMAX/TWO) DIVAXN = MOD(DIVAXO,S) + 1
       BASEST = INTVLS(MINORD)
       FUNCLS = INTCLS + 4*S
       RETURN
```

39

```
        END
C****************************************************************
C****************************************************************
C****************************************************************
        SUBROUTINE SYMRL(S, CENTER, HWIDTH, F, MINORD, MAXORD, INTVLS,
     * INTCLS, NUMSMS, WEGHTS, FULSMS, FAIL)
        IMPLICIT DOUBLE PRECISION (A-H,O-Z)
C  MULTIDIMENSIONAL FULLY SYMMETRIC RULE INTEGRATION SUBROUTINE
C
C   THIS SUBROUTINE COMPUTES A SEQUENCE OF FULLY SYMMETRIC RULE
C   APPROXIMATIONS TO A FULLY SYMMETRIC MULTIPLE INTEGRAL.
C   WRITTEN BY A. GENZ, MATHEMATICAL INSTITUTE, UNIVERSITY OF KENT,
C   CANTERBURY, KENT CT2 7NF, ENGLAND
C
C************** PARAMETERS FOR SYMRL  ******************************
C*****INPUT PARAMETERS
C  S      INTEGER NUMBER OF VARIABLES, MUST EXCEED 0 BUT NOT EXCEED 20
C  F      EXTERNALLY DECLARED USER DEFINED REAL FUNCTION INTEGRAND.
C         IT MUST HAVE PARAMETERS (S,X), WHERE X IS A REAL ARRAY
C         WITH DIMENSION S.
C  MINORD INTEGER MINIMUM ORDER PARAMETER.  ON ENTRY MINORD SPECIFIES
C         THE CURRENT HIGHEST ORDER APPROXIMATION TO THE INTEGRAL,
C         AVAILABLE IN THE ARRAY INTVLS.  FOR THE FIRST CALL OF SYMRL
C         MINORD SHOULD BE SET TO 0.  OTHERWISE A PREVIOUS CALL IS
C         ASSUMED THAT COMPUTED INTVLS(1), ... , INTVLS(MINORD).
C         ON EXIT MINORD IS SET TO MAXORD.
C  MAXORD INTEGER MAXIMUM ORDER PARAMETER, MUST BE GREATER THAN MINORD
C         AND NOT EXCEED 20. THE SUBROUTINE COMPUTES INTVLS(MINORD+1),
C         INTVLS(MINORD+2),..., INTVLS(MAXORD).
C  G      REAL ARRAY OF DIMENSION(MAXORD) OF GENERATORS.
C         ALL GENERATORS MUST BE DISTINCT AND NONNEGATIVE.
C  NUMSMS INTEGER LENGTH OF ARRAY FULSMS, MUST BE AT LEAST THE SUM OF
C         THE NUMBER OF DISTINCT PARTITIONS OF LENGTH AT MOST S
C         OF THE INTEGERS 0,1,...,MAXORD-1.  AN UPPER BOUND FOR NUMSMS
C         WHEN S+MAXORD IS LESS THAN 19 IS 200
C******OUTPUT PARAMETERS
C  INTVLS REAL ARRAY OF DIMENSION(MAXORD).  UPON SUCCESSFUL EXIT
C         INTVLS(1), INTVLS(2),..., INTVLS(MAXORD) ARE APPROXIMATIONS
C         TO THE INTEGRAL.  INTVLS(D+1) WILL BE AN APPROXIMATION OF
C         POLYNOMIAL DEGREE 2D+1.
C  INTCLS INTEGER TOTAL NUMBER OF F VALUES NEEDED FOR INTVLS(MAXORD)
C  WEGHTS REAL WORKING STORAGE ARRAY WITH DIMENSION (NUMSMS). ON EXIT
C         WEGHTS(J) CONTAINS THE WEIGHT FOR FULSMS(J).
C  FULSMS REAL WORKING STORAGE ARRAY WITH DIMENSION (NUMSMS). ON EXIT
C         FULSMS(J) CONTAINS THE FULLY SYMMETRIC BASIC RULE SUM
C         INDEXED BY THE JTH S-PARTITION OF THE INTEGERS
C         0,1,...,WORD-1.
C  FAIL   INTEGER FAILURE OUTPUT PARAMETER
C         FAIL-0 FOR SUCCESSFUL TERMINATION OF THE SUBROUTINE
C         FAIL-1 WHEN NUMSMS IS TOO SMALL FOR THE SUBROUTINE TO
C                CONTINUE.  IN THIS CASE WEGHTS(1), WEGHTS(2), ...,
C                WEGHTS(NUMSMS), FULSMS(1), FULSMS(2), ...,
```

```
C                        FULSMS(NUMSMS) AND INTVLS(1), INTVLS(2),...,
C                        INTVLS(J) ARE RETURNED, WHERE J IS MAXIMUM VALUE OF
C                        MAXORD COMPATIBLE WITH THE GIVEN VALUE OF NUMSMS.
C              FAIL=2 WHEN PARAMETERS S,MINORD, MAXORD OR G ARE OUT OF
C                        RANGE
C************************************************************************
      EXTERNAL F
C***  FOR DOUBLE PRECISION CHANGE REAL TO DOUBLE PRECISION
C      IN THE NEXT STATEMENT
      INTEGER D, I, FAIL, K(20), INTCLS, PRTCNT, L, M(20), MAXORD,
     * MINORD, MODOFM, NUMSMS, S, SUMCLS
      DOUBLE PRECISION INTVLS, INTMPA, INTMPB
      DOUBLE PRECISION MOMTOL, INTVAL, MOMENT, MOMPRD, MOMNKN
      DIMENSION INTVLS(MAXORD), CENTER(S), HWIDTH(S)
      DIMENSION FULSMS(NUMSMS), WEGHTS(NUMSMS)
      DIMENSION MOMPRD(20,20), MOMENT(20), G(20)
C       PATTERSON GENERATORS
      DATA G(1), G(2)  /0.0000000000000000,0.7745966692414833/
      DATA G(3), G(4) /0.9604912687080202,0.4342437493468025/
      DATA G(5), G(6)  /0.9938319632127549,0.8884592328722569/
      DATA G(7), G(8)  /0.6211029467372263,0.2233866864289668/
      DATA G(9), G(10), G(11), G(12) /0.1, 0.2, 0.3, 0.4/
C
C***  PARAMETER CHECKING AND INITIALISATION
      FAIL = 2
      MAXRDM = 20
      MAXS = 20
      IF (S.GT.MAXS .OR. S.LT.1) RETURN
      IF (MINORD.LT.0 .OR. MINORD.GE.MAXORD) RETURN
      IF (MAXORD.GT.MAXRDM) RETURN
      ZERO = 0
      ONE = 1
      TWO = 2
      MOMTOL = ONE
   10 MOMTOL = MOMTOL/TWO
      IF (MOMTOL+ONE.GT.ONE) GO TO 10
      HUNDRD = 100
      MOMTOL = HUNDRD*TWO*MOMTOL
      D = MINORD
      IF (D.EQ.0) INTCLS = 0
C***  CALCULATE MOMENTS AND MODIFIED MOMENTS
      DO 20 L=1,MAXORD
        FLOATL = L + L - 1
        MOMENT(L) = TWO/FLOATL
   20 CONTINUE
      IF (MAXORD.EQ.1) GO TO 50
      DO 40 L=2,MAXORD
        INTMPA = MOMENT(L-1)
        GLSQRD = G(L-1)**2
        DO 30 I=L,MAXORD
          INTMPB = MOMENT(I)
          MOMENT(I) = MOMENT(I) - GLSQRD*INTMPA
```

41

```
              INTMPA = INTMPB
       30     CONTINUE
              IF (MOMENT(L)**2.LT.(MOMTOL*MOMENT(1))**2) MOMENT(L) = ZERO
       40 CONTINUE
       50 DO 70 L=1,MAXORD
              IF (G(L).LT.ZERO) RETURN
              MOMNKN = ONE
              MOMPRD(L,1) = MOMENT(1)
              IF (MAXORD.EQ.1) GO TO 70
              GLSQRD = G(L)**2
              DO 60 I=2,MAXORD
                IF (I.LE.L) GISQRD = G(I-1)**2
                IF (I.GT.L) GISQRD = G(I)**2
                IF (GLSQRD.EQ.GISQRD) RETURN
                MOMNKN = MOMNKN/(GLSQRD-GISQRD)
                MOMPRD(L,I) = MOMNKN*MOMENT(I)
       60     CONTINUE
       70 CONTINUE
          FAIL = 1
C
C***  BEGIN LOOP FOR EACH D
C       FOR EACH D FIND ALL DISTINCT PARTITIONS M WITH MOD(M))=D
C
       80 PRTCNT = 0
          INTVAL = ZERO
          MODOFM = 0
          CALL NXPRT(PRTCNT, S, M)
       90 IF (PRTCNT.GT.NUMSMS) RETURN
C
C***  CALCULATE WEIGHT FOR PARTITION M AND FULLY SYMMETRIC SUMS
C***      WHEN NECESSARY
C
          IF (D.EQ.MODOFM) WEGHTS(PRTCNT) = ZERO
          IF (D.EQ.MODOFM) FULSMS(PRTCNT) = ZERO
          FULWGT = WHT(S,MOMENT,M,K,MODOFM,D,MAXRDM,MOMPRD)
          SUMCLS = 0
          IF (WEGHTS(PRTCNT).EQ.ZERO .AND. FULWGT.NE.ZERO) FULSMS(PRTCNT) =
         * FLSM(S, CENTER, HWIDTH, MOMENT, El, K, W O R D , G, F, SUMCLS)
          INTCLS = INTCLS + SUMCLS
          INTVAL = INTVAL + FULWGT*FULSMS(PRTCNT)
          WEGHTS(PRTCNT) = WEGHTS(PRTCNT) + FULWGT
          CALL NXPRT(PRTCNT, S, M)
          IF (M(1).GT.MODOFM) MODOFM = MODOFM + 1
          IF (MODOFM.LE.D) GO TO 90
C
C***  END LOOP FOR EACH D
          IF (D.GT.0) INTVAL = INTVLS(D) + INTVAL
          INTVLS(D+1) = INTVAL
          D = D + 1
          IF (D.LT.MAXORD) GO TO 80
C
C***  SET FAILURE PARAMETER AND RETURN
```

```
        FAIL = 0
        MINORD = MAXORD
        RETURN
        END
        SUBROUTINE NXPRT(PRTCNT, S , M)
        IMPLICIT DOUBLE PRECISION (A-H,O-Z)
C
C***   SUBROUTINE TO COMPUTE THE NEXT S PARTITION
C
        INTEGER S , M(S), PRTCNT, I , MSUM
        IF (PRTCNT.GT.0) GO TO 20
        DO 10 I=1,S
          M(I) = 0
   10 CONTINUE
        PRTCNT = 1
        RETURN
   20 PRTCNT = PRTCNT + 1
        MSUM = M(1)
        IF (S.EQ.1) GO TO 60
        DO 50 I=2,S
          MSUM = MSUM + M(I)
          IF (M(1).LE.M(I)+1) GO TO 40
          M(1) = MSUM - (I-1)*(M(I)+1)
          DO 30 L=2,I
            M(L) = M(I) + 1
   30     CONTINUE
          RETURN
   40     M(I) = 0
   50 CONTINUE
   60 M(1) = MSUM + 1
        RETURN
        END
C***************************************************************************
C***************************************************************************
C***************************************************************************
        DOUBLE PRECISION FUNCTION WHT
     .        (S, INTRPS, M, K, MODOFM, D, MAXRDM, MOMPRD)
        IMPLICIT DOUBLE PRECISION (A-H,O-Z)
C***   SUBROUTINE TO CALCULATE WEIGHT FOR PARTITION M
C
        INTEGER S, M(S), K(S), D, MAXRDM, MI, KI, M1, K1, MODOFM
        DOUBLE PRECISION INTRPS, MOMPRD
        DIMENSION INTRPS(S), MOMPRD(MAXRDM,MAXRDM)
        ZERO = 0
        DO 10 I=1,S
          INTRPS(I) = ZERO
          K(I) = 0
   10 CONTINUE
        M1 = M(1) + 1
        K1 = D - MODOFM + M1
   20 INTRPS(1) = MOMPRD(M1,K1)
        IF (S.EQ.1) GO TO 40
```

```
      DO 30 I=2,S
        MI = M(I) + 1
        KI = K(I) + MI
        INTRPS(I) = INTRPS(I) + MOMPRD(MI,KI)*INTRPS(I-1)
        INTRPS(I-1) = ZERO
        K1 = K1 - 1
        K(I) = K(I) + 1
        IF (K1.GE.M1) GO TO 20
        K1 = K1 + K(I)
        K(I) = 0
   30 CONTINUE
   40 WHT = INTRPS(S)
      RETURN
      END
C******************************************************************
C******************************************************************
C******************************************************************
      DOUBLE PRECISION FUNCTION FLSM
     .    (S,CENTER,HWIDTH,X,M,MP,MAXORD,G,F,SUMCLS)
      IMPLICIT DOUBLE PRECISION (A-H,O-Z)
      EXTERNAL F
C
C***  FUNCTION TO COMPUTE FULLY SYMMETRIC BASIC RULE SUM
C
      INTEGER S , M(S), MP(S), W O R D, SUMCLS, IXCHNG, LXCHNG, I, L,
     * IHALF, MPI, MPL
      DOUBLE PRECISION INTWGT, INTSUM
      DIMENSION G(MAXORD), X(S)
      DIMENSION CENTER(S), HWIDTH(S)
      ZERO = 0
      ONE = 1
      TWO = 2
      INTWGT = ONE
      DO 10 I=1,S
        MP(I) = M(I)
        IF (M(I).NE.0) INTWGT = INTWGT/TWO
        INTWGT = INTWGT*HWIDTH(I)
   10 CONTINUE
      SUMCLS = 0
      FLSM = ZERO
C
C*******  COMPUTE CENTRALLY SYMMETRIC SUM FOR PERMUTATION MP
   20 INTSUM = ZERO
      DO 30 I=1,S
        MPI = MP(I) + 1
        X(I) = CENTER(I) + G(MPI)*HWIDTH(I)
   30 CONTINUE
   40 SUMCLS = SUMCLS + 1
      INTSUM = INTSUM + F(S,X)
      DO 50 I=1,S
        MPI = MP(I) + 1
        IF(G(MPI).NE.ZERO) HWIDTH(I) = -HWIDTH(I)
```

```fortran
          X(I) = CENTER(I) + G(MPI)*HWIDTH(I)
          IF (X(I).LT.CENTER(I)) GO TO 40
   50 CONTINUE
C*******   END INTEGRATION LOOP FOR MP
C
      FLSM = FLSM + INTWGT*INTSUM
      IF (S.EQ.1) RETURN
C
C*******   FIND NEXT DISTINCT PERMUTATION OF M AND LOOP BACK
C          TO COMPUTE NEXT CENTRALLY SYMMETRIC SUM
      DO 80 I=2,S
        IF (MP(I-1).LE.MP(I)) GO TO 80
        MPI = MP(I)
        IXCHNG = I - 1
        IF (I.EQ.2) GO TO 70
        IHALF = IXCHNG/2
        DO 60 L=1,IHALF
          MPL = MP(L)
          IMNUSL = I - L
          MP(L) = MP(IMNUSL)
          MP(IMNUSL) = MPL
          IF (MPL.LE.MPI) IXCHNG = IXCHNG - 1
          IF (MP(L).GT.MPI) LXCHNG = L
   60   CONTINUE
        IF (MP(IXCHNG).LE.MPI) IXCHNG = LXCHNG
   70   MP(I) = MP(IXCHNG)
        MP(IXCHNG) = MPI
        GO TO 20
   80 CONTINUE
C*****   END LOOP FOR PERMUTATIONS OF M AND ASSOCIATED SUMS
C
      RETURN
      END
C***************************************************************************
C***************************************************************************
C***************************************************************************
      DOUBLE PRECISION FUNCTION QFCLG(NDIM,Z)
C***    This function computes the convective heat transfer flux to
C***  the ceiling at location (X,Y)=(Z(1),Z(2))
        IMPLICIT DOUBLE PRECISION (A-H,O-Z)
      DIMENSION Z(2)
      COMMON/AINTCH/H,HTCT,THT,THTQHP,C1,C2,C3,XF,YF,TC
      X=Z(1)
      Y=Z(2)
      R=((X-XF)**2.D0+(Y-YF)**2.D0)**(1.D0/2.D0)
      RDH=R/H
      FF=(1.D0-1.1D0*(RDH**0.8D0)+0.808D0*(RDH**1.6D0))/
     +          (1.D0-1.1D0*(RDH**0.8D0)+2.2D0*(RDH**1.6D0)+
     +                                   0.69D0*(RDH**2.4D0))
      IF(RDH.LT.0.2D0)THEN
            HTCLDH=C1*(1.D0-C2*RDH)
            TADDIM=10.22D0-14.9D0*RDH
```

```
      ELSE
            HTCLDH=C3*(1.D0/(RDH**1.2D0))*(RDH-0.0771D0)/
     +                                       (RDH+0.279D0)
            TADDIM=8.390913361D0*FF
      ENDIF
      HTCL=HTCLDH*HTCT
      TAD=TADDIM*THTQHP+THT
      QFCLG=HTCL*(TAD-TC)
      RETURN
      END
C***************************************************************
```

Figure 1. Fire in a rectangular parallelopiped enclosure.

47

Figure 2. The fire and the equivalent source in the lower layer and the continuation source in the extended upper layer.

Figure 3. Overview of the CEILI-IT Algorithm.

Call CEILHT

is $Z_{FIRE} < Z_{LAY}$

yes — calculate $\dot{Q}_{EQ}^*$ and Z_{EQ} from Eqs. (5)-(6)

no — is $Z_{FIRE} = Z_{CEIL}$

yes — fire is at ceiling; cant ceiling jet and vective heat transfer

no — calculate $\dot{Q}'$ and Z_{SOURCE}' from bottom of Eq. (11') and bottom of Eq. (12')

is $Z_{LAY} < Z_C$

calculate a, σ, and $\dot{M}^*$ from Eqs. (7)-(9)

Is $\dot{M}^* > 0$

yes / no

There is no penetra- and no significant ceiling jet or convective heat transfer

Calculate $\dot{Q}'$ and Z_{SOURCE}' from the top of Eq. (11') and the middle of Eq. (12')

calculate $\dot{Q}'$ and Z_{SOURCE}' from bottom of Eq. (11') and top of Eq. (12')
NOTE: when using Eqs. (15), (18), and (19) below replace T_U with T_L

calculate $\dot{Q}_{CEIL}$ from the integral of Eq. (2) using Eqs. (13)-(17) and (19); calculate $q_{WALL,L,AVE}''$, $q_{WALL,U,AVE}''$, and $\dot{Q}_{WALL}$ from Eqs. (20)-(27) and (A-1)-(A-6)

39

Figure 4. A plot of dimensionless ceiling jet velocity distribution, V_{CJ}/V_{MAX}, as a function of $z/(0.23\delta)$ per Eq. (29).

50

$$\Theta = (T_{CJ} - T_U)/(T_{MAX} - T_U)$$

Figure 5. Plots of dimensionless ceiling jet temperature distribution, Θ, as a function of $z/(0.23\delta)$ per Eq. (32) for cases when Θ_S is < 0, between 0 and 1, and > 0.

Figure 6. Definition of the Wall Stagnation Points, Room Corners, and Wall Segments.

TITLE AND SUBTITLE
FIRE-PLUME-GENERATED CEILING JET CHARACTERISTICS AND CONVECTIVE HEAT TRANSFER TO CEILING **AND** WALL **SURFACES** IN **A** TWO-LAYER ZONE-TYPE FIRE ENVIRONMENT: UNIFORM TEMPERATURE CEILING **AND** WALLS

AUTHOR(S)

Leonard Y. Cooper

PERFORMING ORGANIZATION (IF JOINT OR OTHER THAN NIST, SEE INSTRUCTIONS)

U.S. DEPARTMENT OF COMMERCE
NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY
GAITHERSBURG, MD 20899

7. CONTRACT/GRANT NUMBER

8. F OF IEP)RT AND PERIOD COVERED

0. SUPPLEMENTARY NOTES

1. ABSTRACT (A 200-WORD OR LESS FACTUAL SUMMARY OF MOST SIGNIFICANT INFORMATION. IF DOCUMENT INCLUDES A SIGNIFICANT BIBLIOGRAPHY OR LITERATURE SURVEY, MENTION IT HERE.)

It has been determined by Sandia National Laboratories and the US Nuclear Regulatory Commission that the use of deterministic, multi-room, zone-type fire modeling technology could enhance the reliability of their recent reactor safety risk studies. These studies are confined to the relatively early detection times of fire development when fire-driven ceiling jets and gas-to-ceiling convective heat transfer are expected to play a particularly important role in room-to-room smoke spread and in the response of near-ceiling mounted detection hardware. A parameter of concern in these risk analyses is the location of the fire within the space of fire origin. One goal of the analyses is to determine the significance to risk of this fire-position parameter.

This work presents a model to predict the instantaneous rate of convective heat transfer from fire plume gases to the overhead ceiling surface in a room of fire origin. The room is assumed to be a rectangular parallelopiped and, at times of interest, ceiling temperatures are simulated as being uniform. Also presented is an estimate of the convective heat transfer, due to ceiling-jet-driven wall flows, to both the upper and lower portions of the walls. The effect on the heat transfer of the location of the fire within the room is taken into account. Finally presented is a model of the velocity and temperature distributions in the ceiling jet.

The model equations were used to develop an algorithm and associated modular computer subroutine to carry out the indicated heat transfer calculations, The subroutine is written in FORTRAN **77** and called CEILHT The algorithm and subroutine are suitable for use in two-layer zone-type compartment fire model computer codes.

12. KM WORDS (6 TO 12 ENTRIES; ALPHABETICAL ORDER; CAPITALIZE ONLY PROPER NAMES; AND SEPARATE KEY WORDS BY SEMICOLONS)

building fires; ceiling jets; **compartment** fires; computer models; fire models; heat transfer; mathematical models; zone models

3. AVAILABILITY

X UNLIMITED

FOR OFFICIAL DISTRIBUTION. DO NOT RELEASE TO NATIONAL TECHNICAL INFORMATION SERVICE (NTIS).

ORDER FROM SUPERINTENDENT OF DOCUMENTS, U.S. GOVERNMENT PRINTING OFFICE. WASHINGTON, DC 20402.

X ORDER FROM NATIONAL TECHNICAL INFORMATION SERVICE (NTIS). SPRINGFIELD. VA 22161.

14. NUMBER OF PRINTED PAGES

57

15. PRICE

A04